State	Reno	rt	Info

School NCES ID	n/a			
Name of School	Putnam Co. R-I			
Address	803 S 20th			
	Unionville, MO 63565-1482			
Type of Facility	Public			
Program Remediation trigger	5pbb			
School District	Putnam Co. R-I			
Sampling Begin Date	6/27/2023			
Sampling End Date	11/26/2024			
Number of Sample Points tested		117		
Number of Samples with lead Detected		46		
Percentage of Samples with Lead Detected		39.3%		
Number of Samples with lead Detected Above the Program Remediation Trigger		27		
Percentage of Samples with Lead Above the Remediation Level		23.08%		
Lab Reporting Limit		1.0		
Number of potential drinking outlets inventoried.		117		
Total number of samples collected and tested		161		
Summary of drinking water outlet type (≥5ppb) in the following outlet categories at each facility/campus location based on initial samples				

summary of drinking water outlet type (25ppb) in the following outlet categories at each facility/campus location based on initial samples									
OUTLET TYPE		ELEMENTARY		MIDDLE SCHOOL		HIGH SCHOOL			
Fountains/bottle fillers	2		2		2				
kitchen outlets								4	
bathroom outlets								4	
Classroom		2						3	
ice makers								1	
hot drink machines									
other outlets-Hydrants, showers etc.								7	
Total FAILED OUTLETS		4			2			21	
TOTAL # of outlets at each facility									
TOTAL # OF SAMPLES COLLECTED/FACILITY	INITIAL	FLUSH	REMEDIA L	INITIAL	FLUSH	REMEDIA L	INITIA L	FLUS H	REMEDIA L
	30	5	5	7	2	2	80	20	10

Summary of remediation methods		
Number of outlets replaced		
Number of outlets repaired		
Number of filters installed		
Number of outlets taken out of service		
Number of other (signage posted)		
Were interior pipes replaced		
Number of outlets tested post remediation		
Additional Information		

Additional Information

4 water Main Test Points and 12 showers are included in the total number of test points.