

State Report Info

School NCES ID	n/a
Name of School	Putnam Co. R-I
Address	803 S 20th
	Unionville, MO 63565-1482
Type of Facility	Public
Program Remediation trigger	5ppb
School District	Putnam Co. R-I
Sampling Begin Date	6/27/2023
Sampling End Date	11/26/2024
Number of Sample Points tested	117
Number of Samples with lead Detected	46
Percentage of Samples with Lead Detected	39.3%
Number of Samples with lead Detected Above the Program Remediation Trigger	27
Percentage of Samples with Lead Above the Remediation Level	23.08%
Lab Reporting Limit	1.0
Number of potential drinking outlets inventoried.	117
Total number of samples collected and tested	161

Summary of drinking water outlet type (≥5ppb) in the following outlet categories at each facility/campus location based on initial samples									
OUTLET TYPE	ELEMENTARY			MIDDLE SCHOOL			HIGH SCHOOL		
Fountains/bottle fillers	2			2			2		
kitchen outlets							4		
bathroom outlets							4		
Classroom	2						3		
ice makers							1		
hot drink machines									
other outlets-Hydrants, showers etc.							7		
Total FAILED OUTLETS	4			2			21		
TOTAL # of outlets at each facility									
TOTAL # OF SAMPLES COLLECTED/FACILITY	INITIAL	FLUSH	REMEDIATION	INITIAL	FLUSH	REMEDIATION	INITIAL	FLUSH	REMEDIATION
	30	5	5	7	2	2	80	20	10

Summary of remediation methods	
Number of outlets replaced	
Number of outlets repaired	
Number of filters installed	
Number of outlets taken out of service	
Number of other (signage posted)	
Were interior pipes replaced	
Number of outlets tested post remediation	
Additional Information	
4 water Main Test Points and 12 showers are included in the total number of test points.	