ROE Compliance Recommendations:

Recommendation	Notes	Photo for Reference
No Daisy Chaining		
Power Strips need to be UL approved with the label in tact		02/98 LISTED RELOCATABLE POWER TAP 34C4
Curtains/Blinds must be fire proof and not covering line of site into classroom	Need Admin Approval	
Lamps/Christmas Lights/LED lights	Must contain UL label and be admin approved	Auxilliary Switch Model: ZW2001 For use with GE 2-Wave switches or dismers 120 Votes AC, 60Hz GRN Ground Whiff w RED! Neutroc VEL. To Dammer switch Date Code: 0946 MACD Predecin, Usikinghor Oity, Oit Welliams of Chine
No candles or warmers in classrooms		
Any Outside Furniture	Need Admin Approval	

Shelving	Any items on shelves must be 18 inches below the ceiling	
Storage closets	If your room contains a bathroom or storage closet you must not have anything blocking the door and able to fully access storage closet or bathroom	
Outlet SafetyCovers	Any outlet not in use	