



Arkadelphia Public Schools
Director of Support Services
Jimmy King



September Maintenance Report

- The new LED stadium light equipment has been installed and looks great! Going into this project I knew that our original breaker panels and wiring were in bad shape. I have contracted with the installer to come back and replace all four breaker panels on the light poles and run all new wiring to the lights. We are currently waiting on the breaker panels to come in.
- The last storm we had a few weekends ago caused quite a bit of damage to some of our electrical systems. We lost one air handler motor that controlled 25% of the air conditioning at AHS, one exhaust fan motor on the vent hood in the AHS cafeteria, two exhaust fan motors in the gym at AHS, damage to the transformer and parking lot lights at Goza Middle School, five wall pack security led lights at Badger Stadium, one GFI outlet on the 25 sec clock at Badger Stadium, and two contactors for the lights in the old band room at old Goza. Everything has been repaired except for the two exhaust fan motors at the AHS gym. Those motors have been backordered and we are waiting for them to be shipped when they become available again.
- Besides the issues already mentioned, all other calls for repairs have been for just general routine maintenance issues.