

AIO™ Ceiling Suspended (with ERV Option) Shroud Extension (R120295A299)

Installation Instructions




INSTRUCTIONS

To install the AIO™ Ceiling Suspended Shroud Extension::


1. Disconnect the power supply from the unit
2. Install the four brackets at the corners of the unit's exterior.

Figure 1. Installing the four brackets




3. Remove the insulation from the four corners to locate the holes.
4. Using the supplied screws, secure the four brackets to the unit.
5. Reposition the insulation on the unit (if necessary, use double-sided tape).
6. Using the supplied screws, install the two side covers on the brackets.

Figure 2. Installing the two side covers



7. Secure the bottom cover magnetically.


Figure 3. Securing the bottom cover





With over 20 years of experience in the climate comfort sector, we have a clear goal: growth through innovation. Our team is laser-focused on the conception, development, and production of innovative heating, ventilation, and air conditioning solutions. This mission has developed through bringing together technical skills, creativity, technology, design, Italian passion, and a global vision to achieve the best energy efficiency and performance.

innova.co | **USA:** 216-710-1000 **Canada:** 416-739-1000



© 2026 INNOVA. All rights reserved.

Revised June 23, 2026

AIO™ Ceiling Suspended (with ERV Option) Shroud
Extension (R120295A299) **Installation Instructions**