



Arkadelphia Public Schools
Director of Support Services
Jimmy King



May Maintenance Report

- All of our annual fire alarm and boiler inspections have been completed.
- Roof top unit (RTU-#6) on the Peake cafeteria has finally been repaired. We had been having issues with that unit shutting down and repair techs could not diagnose the problem. Nabholz got Gigerich Electric, Powers of Arkansas, and Middleton Heating & Air all here at the same time and finally figured out that two hot wires leading to the two fan motors on top of the unit were shorted out and causing the unit to shut down.
- We are still having issues with the Goza elevator not working properly. We are working with TKE Elevator to get this problem corrected.
- Carrier came this week to do some preventative maintenance work on the chiller at the high school.