

1. SCOPE

This specification sets the minimum acceptable requirements for supply of non-modulating float valves type for size range of DN100 – DN1000mm.

2. APPLICABLE STANDARDS

EN 1074-1	Valves for water supply – Part 1: Fitness for purpose req. and Appropriate verification tests (General Req.)
EN 1074-5	Valves for water supply – Part 5: Fitness for purpose req. and Appropriate verification tests (Control valves.)
EN 12266-1	Testing of valves Part 1: Pressure tests, test procedures and acceptable criteria - Mandatory requirements – (Industrial valves)
ISO5752	Face to face dimensions of valves
ISO 7005	Metallic flanges
ISO5208	Industrial valves, Pressure testing of metallic valves
EN 1092	Flanges and their joints – Part 2: Cast Iron flanges, Circular flanges for pipes, valves, fittings and accessories, PN designated
EN1563/DIN 1693	Spheroidal graphite cast iron

1. General description

The valve allows flow into the reservoir to the maximum high level where it closes drip tight. The valve remains closed when the reservoir level drops until the float reaches the predetermined minimum reservoir level at which time it opens to refill the reservoir. The valve shall be of the double flanged type, of ductile cast iron. Operation shall be by the use of an integral auxiliary actuating mechanism (Pilot system) suitable for the application.

2. Flange Drilling

Flanges shall be designed to comply with ISO 7005 and BSEN 1092-2. Flange drilling shall be PN10 or PN16 according to project requirement.

3. Body description for diaphragm types

Valves shall be a hydraulically operated diaphragm actuated globe valve. The valve is operated by introducing or releasing water from the control chamber above the diaphragm. The inner valve assembly shall be top and bottom guided by means of easily replaceable bearing bushings. The inner valve assembly shall be the only moving part and shall be securely mounted on a stainless steel stem.

Valves shall provide smooth motion with actuation being achieved by the use of an EPDM or NBR diaphragm. They shall be constructed of nylon or wool fabric bonded with synthetic rubber. The diaphragms shall not be used as a seating surface.

The valves shall form a drip tight seal between the stationary stainless steel seat ring and the resilient disc, which has a rectangular cross-section and is retained by clamping. The resilient disc shall be constructed of Buna or EPDM for normal service conditions.

All repairs and maintenance shall be possible without removing the valve from the line. To facilitate easy removal and replacement of the inner valve assembly and to reduce unnecessary wear on the guide, the stem shall be vertical when the valve is mounted in a horizontal line

4. Pilot system

The pilot shall be of the (3-way) non modulating style and made of stainless steel construction. The pilot shall include stainless steel float & float rod.

The stainless steel float rod shall pivot from the lever located on pilot and shall be with adjustable stops.

The pilot will close the main valve on rising water level.

A needle valve shall be incorporated in the connection from the pilot system to the main valve to adjust the rate of valve closure. Where required a second needle valve can be added to control the rate of opening of the main valve.

5. Hydrostatic Testing

Hydrostatic test of automatic control valve shall be performed on the completely assembled valve and are being tested in four tests:

- Shell Pressure Test.
- Seat Pressure Test.
- Diaphragm or Piston Sealing Test.
- Pilot System Test.

Standard testing is according to ISO5208. Shell test is 1.5times the working pressure, seal test is 1.1times of the working pressure.

6. Coating

All valves shall be internally and externally Epoxy coated to a minimum DFT of 250microns after careful surface preparation. Internal epoxy coating shall be of non toxic type.

7. Materials of Construction

Valve body, Bonnet and disc shall be constructed of ductile iron castings that conform to ISO1083 Grade500-7 or equivalent.

Internal Stainless Steel components (stem and seating faces) shall conform to BS304S15, ASTM276-1967 Grade304 or 316.

Diaphragm shall be constructed of nylon or wool fabric bonded with synthetic rubber.

8. Marking

Marking shall be cast on the body with raised letters or engraved on a separate stainless steel name plate and it may indicates the nominal valve size, manufacturer's name, design pressure rating and the year of manufacture.