

Please contact the Biomedical Engineer or Maintenance department for any abnormality in maintaining the differential air pressure.
(Extension. No: **0000**)

Note: Keep the doors closed at all times. Turn on the AC always.

Normal Range for Negative pressure:

-0.010 to -0.050 WC

-2.488 to -12.442 Pa

Normal Range for Positive pressure:

+ 0.010 to + 0.050 WC

+ 2.488 to + 12.442 Pa