



LITTLE EGG HARBOR TOWNSHIP SCHOOL DISTRICT

307 Frog Pond Road, Little Egg Harbor, NJ 08087
Phone: (609) 296-1719 x 2215, Fax: (609) 296-3225

The Little Egg Harbor Township Board of Education is highly committed to the safety of our students and staff. In compliance with New Jersey Department of Education regulations, lead in water testing for drinking water locations throughout the district was performed on November 4, 2021. The purpose of the sampling was to identify and address any drinking water location above the EPA action level of 15.5 parts per billion (ppb). A drinking water location is an outlet that is designed or expected to be used for water consumption. These included, but were not limited to, classroom water fountains or sinks, water coolers, sinks in nurse's offices, faculty break rooms, and locations in kitchens used for food preparation. Bathroom, custodial, art room, and science room sinks were not sampled, as these are not expected nor designed to be used for water consumption.

Water was allowed to stay motionless in each facility for a minimum of eight hours prior to sampling. After this time of inactivity, an "initial draw" sample was collected from the first water to come out of the outlet. After the initial draw sample was collected, water was allowed to flush for 30 seconds, and a second "flush" sample was collected. The purpose of the flush sample is to help determine if contamination does exist, whether it is originating from the outlet itself or from the building's plumbing.

A summary of each location above the action level, as well as the short-term response, is found below:

Frog Pond Elementary School

SAMPLE LOCATION	FIRST DRAW RESULT	FLUSH SAMPLE RESULT	SHORT TERM RESPONSE
Bubbler – Room 303	21.1 ppb	5.23 ppb	Taken out of service
Bubbler – Room 107	17.2 ppb	2.25 ppb	Taken out of service

Bubbler – Room 403	17.4 ppb	3.61 ppb	Taken out of service
Bubbler – Room 507	22.0 ppb	3.43 ppb	Taken out of service

Mitchell Elementary School

SAMPLE LOCATION	FIRST DRAW RESULT	FLUSH SAMPLE RESULT	SHORT TERM RESPONSE
NONE			

Wood Early Education Center

SAMPLE LOCATION	FIRST DRAW RESULT	FLUSH SAMPLE RESULT	SHORT TERM RESPONSE
NONE			

At this time, permanent solutions for each of these locations are being evaluated. The District will notify staff, students, and parents as these solutions are implemented. If you have any questions, please contact the Facilities Director Seth Cole at (609) 296-1719 ext.2215.