

Table of Contents

1.0	Introduction	2
1.1.	Objectives	3
1.2.	Scope	3
1.2	2.1. Within Scope	4
1.2	2.2. Outside of Scope for This Document	4
2.0	Biometric Device Requirements for SBI 1.0/L0	6
2.1.	Quality Specifications	6
3.0	Testing for MACP: Biometric compliance	8
3.1.	Laboratory Qualification Criteria	8
3.2.	Test Planning	8
3.3.	Reporting the Results	15

1.0 Introduction

It is fairly universally accepted that issuance of identity is a complex exercise. In digital identity systems based on platforms like MOSIP, biometrics, where needed, provide an essential integrity measure for establishing uniqueness. As MOSIP adoptions accelerate across the world, a growing community of partners and vendors are geared up to make MOSIP-compliant biometric devices and solutions available worldwide.

It is important to recognise that the quality of biometric images acquired helps determine the overall efficiency of a system, and has a direct impact on a system's ability to perform deduplication and authentication functions. In order to provide an independent "certification" or "assurance" mechanism for the biometric devices that MOSIP users are deploying, MOSIP has initiated the drafting of a modular, globally adoptable, certification framework.

The objective of this effort, is to:

- Arrive at a framework that provides standardised assessment criteria and standard operating procedures to test devices/solutions against these criteria
- 2. Enable the establishment of standardised MOSIP biometric device certification programmes which are capable of providing independent certifications to MOSIP users

The vision is to arrive at a framework for the assessment of full compliance at the levels of image quality, software interfaces, and hardware-based security implementation levels, in a way that offers meaningful and realistic results. Adopting countries should be able to rely on these results while making decisions on biometric devices in their ecosystems.

An independent mechanism for biometric certification will offer users the flexibility to rely on empanelled, independent laboratories to ascertain the quality of devices. This will reduce the risks and effort associated with establishing full-fledged programmes, which may be resource-intensive and time-consuming.

The decided-upon standard assessment criteria have to be independently adoptable by global laboratories; those that can support both global and

geography-specific needs for compliance; that MOSIP-adopting countries can rely on. These labs will offer an MACP (MOSIP Advanced Compliance Programme) certification; that will be structured with country needs in mind and developed in consultation with the ecosystem.

The framework will be developed in a staged manner, and the output of the work will be published regularly to the ecosystem for their feedback.


1.1. Objectives

High quality enrolment standards must be set so that biometric enrolment and matching can be used accurately in a wide variety of environments and also supporting most, if not all, demographics. It is necessary to have a certification standard that can ensure consistency in the capture quality across different modalities. This also applies to authentication devices.

This document sets out the MOSIP Advanced Compliance Program (MACP) requirements applicable to qualified third-party testing laboratories providing certification of eligible biometric device providers against the respective MACP specifications. A more comprehensive end-to-end framework will be created as the MACP matures over time.

1.2. Scope

Current specifications only relate to requirements set out in this framework for qualified testing labs undertaking biometric device testing related to quality. All other certification activities that are not related to quality testing are out of scope for the current project.



Here, "Registration" corresponds to an individual providing their biometrics to the biometric capture device for enrolment¹.

1.2.1. Within Scope

- Specifications for testing for compliance to the MACP quality standards for face, finger, and iris modalities
- Sample quality compliance report
- Standards compliant delivery of biometric samples

1.2.2. Outside of Scope for This Document

- All non-quality certification including:
 - Accuracy and vulnerability components within the MOSIP ecosystem architecture
 - o Biometric algorithm requirements
 - o Security and fraud control requirements
 - o Risk management, usability testing
 - o Durability testing
 - o Technical testing
 - o General IT requirements
 - o Privacy, and governance

¹ The terms 'enrolment' is used throughout the document for consistency and simplicity.

• All relevant non-quality related parameters and their assessment framework will be appended to the master certification framework document. Quality is one section in the overall framework.

2.0 Biometric Device Requirements for SBI 1.0/L0

Biometric device requirements include:

Any biometric device tested for MACP compliance will be integrated with the MOSIP Software. Therefore, verification that the biometric device is communicating with the MOSIP structure properly is the first step towards ensuring compliance to MOSIP requirements.

Other requirements are listed in the sections below.

2.1. Quality Specifications

Table 1 MACP Quality Specifications Overview

Criteria	Description	
Test Planning		
Test Plan	The test plan document is compliant with section 3.2 of this	
	document	
Testing		
Test Execution	The test execution is informed by section 3.2 of this	
	document and requirements on Image Quality and Image	
	Formats.	
Image Quality	Image acquisition errors such as failure to enrol which is the	
	expected proportion of the population for whom the system	
	is unable to generate repeatable templates. This will include	
	those unable to present the required biometric feature,	
	those unable to produce an image of sufficient quality at	
	enrolment. The failure to enrol rate will depend on the	
	enrolment policy. For example, in the case of failure to enrol,	
	enrolment might be re-attempted later.	
	Quality	
	1. Compliance	
	a. Face/Finger/Iris: Current MOSIP	
	Compliance specifications for ISO/IEC 19794	
	series (Biometric Specification - MOSIP	
	Docs 1.1.5)	
	2. Best Practice	

Criteria	Description	
Test Planning		
	a. Compliance to the specifications of Image	
	Quality Standards and Technical Reports	
	is considered best practice:	
	i. ISO/IEC 29794-2:2017- Biometric	
	Sample Quality (Finger Image Data)	
	ii. ISO/IEC 29794-6:2015- Biometric	
	Sample Quality (Iris Image Data)	
	iii. ISO/IEC 29794-5:2010- Technical	
	Report for Biometric Sample Quality	
	(Face Image Data) ²	
	iv. ISO/IEC 24358: Specifications for	
	face-aware capture subsystems	
	v. Compliance to NFIQ 2 for enrolment	
	and NFIQ 1 for authentication	
	fingerprint devices	
Image Formats	Image formats are compliant with the MOSIP Docs 1.1.5	
	Biometric Specification: Image Formats for Fingerprint, Iris,	
	and Face Capture (as applicable)	
Test Reporting		
Test Report	The test report document is compliant with section 3.3 of	
	this document	

² Working draft to be published

3.0 Testing for MACP: Biometric compliance

3.1. Laboratory Qualification Criteria

Biometric testing must be conducted by a qualified, third-party, biometrics testing entity which, at minimum, displays the following characteristics:

- Be a certified ISO 17025 laboratory
- Has the ability to provide relevant policies and procedures for working with human test subjects that have been approved by a relevant national body. The lab shall implement this policy to:
 - ensure the physical and psychological well-being of human subjects throughout testing.
 - o act as a safeguard to prevent against ethical judgement errors
 - o ensure that human subject testing complies with applicable national legislation
- At a minimum has personnel with demonstrated expertise in biometric evaluation (more than two years), and can provide evidence of proficiency in standardised ISO compliant biometric testing and reporting
- Is able to show evidence that they are an independent entity with no apparent or actual conflict of interest³

3.2. Test Planning

The test plan document shall be informed by the recommendations of the following standards and frameworks, as applicable for the test type planned i.e., scenario, technology type evaluation⁴, in conjunction with other applicable standards and frameworks:

- ISO/IEC 19795-1 (2021)
- ISO/IEC 19795-2 (2007)
- ISO/IEC 19795-3 (2007)

³ NOTE: an entity accredited to perform Biometric Testing under the NVLAP coordinated by NIST would meet the above requirements.

⁴ Refer to ISO/IEC 19795-1:2021 for evaluation definitions

The tables below provides guidance and recommendations for the testing laboratories to prepare the original test plan. The test planning is directed by the MACP compliance requirements as listed in Table 1 MACP Quality Specifications Overview, and is constrained by characteristics of the biometric device tested and specific requirements which should not be altered for the purpose of testing.

The test plan shall specify:

- Target of Evaluation
- Data overview
- Planned evaluation methodology including the metrics that will be calculated

The test plan shall not specify the method(s) by which the biometric device implements its functions, as it is the responsibility of the biometric device to perform its functions in its own way.

To prepare for an MACP evaluation test plan, the evaluator should refer to the table below to determine:

- Which recommendations are implemented
- Which approach is used to verify MACP compliance and what it entails for the data collected

Deviations must be included in the final test report, along with a reasonable justification.

Comments from WG on Device Profile for face modality.

"Some of this should be informed by ISO/IEC 24358 – Face-aware capture subsystem specifications"

NOTE: It is key to note that in real-world laboratory testing, a device profile approach for various deployment use cases is proposed. These device profiles will be included over time in the framework itself and informed by the exploratory testing undertaken on various device types to have requirements in relation to number of people, environmental conditions etc.

Table 2 Summary of recommendations for test plan preparation

Item	Requirement	Description	Specification		
	Category				
Target of	Requirements	Single operating	YES		
evaluation⁵	for the	threshold			
	biometric	Documented device			
	device to be	enrolment policy			
	tested for	covering the			
	МАСР	maximum number of			
	Compliance	enrolment attempts			
		allowed in a			
		transaction			
	Data	Ability to export	1		
	accessibility	results			
Data	Subject	Collected data should	Age	Distribution	
Collection	Diversity ⁶	be diverse with regard	18-30 25-40%		
		to age ⁷	31-50	25-40%	
			51-70	25-40%	
		Collected data should	Gender	Distribution	
		be diverse with regard	Male	40-60%	
		to gender	Female 40-60%		
		Collected data should	A biometric syste	A biometric system tuned to a	
		be diverse with regard	specific target population can		
		to ethnic origin	perform less well if used with a		
		Comments from WG:	different ethnic mix. Hence, the		
		feasible ways to avoid	dataset to be utilised for testing		
		multiple runs per	shall be reflective of the target		
		demographic.	populations' ethnic origins		
		"one approach could			
		be country PoC's"			
	Subject	The evaluator should	YES		
	Training	provide written or			
		verbal instructions to			
		the participating test			
		subjects			

⁵ ISO/IEC 19795-9 (2019)

⁶ ISO/IEC 19795-5 (2011)

⁷ The age group and gender demographic distributions are informed by the ISO/IEC 19795-5 standard. As the framework matures overtime, considerations can be made to modify these distributions in accordance with the target deployment use-case. For instance, inclusion of under 18 age groups for national identity use case.

Item	Requirement	Description	Specification
	Category		
	Subject	Minimum number of	The evaluator must employ at
	Collection	subjects	least 10 unique and
			demographically diverse
			individuals.
			Due to practical limitations on
			test corpus size for quality
			assessment the core focus must
			be on testing under various
			environmental conditions that
			affect quality.
			For each modality there will be a
			device profile that will specify the
			range of conditions to be tested.
	Test Case	Are the planned test	YES
	suitability	cases relevant for the	
		selected device profile	
		Are the planned test	
		cases representative	
		of the biometric	
		device use case?	
		Do the planned test	
		cases allow the	
		evaluator to	
		understand how the	
		solution performs in	
		less optimal	
		environmental	
		conditions (e.g.,	
		poorer lighting, high	
		humidity, poor user	
		compliance)	
		During test planning	
		and dataset collection,	
		have considerations	
		been made for factors	
		influencing quality	
		e.g., environmental	
		variables, age of	
		samples etc.?	

Item	Requirement	Description	on	Specification
	Category			
Lab	Methodology	Biometr	Failure to	For FTEs: explanation on what
Evaluation	and biometric	ic	Enrol (FTE)	constitutes the FTE is
	failure criteria			recommended.
				FTE should be calculated to get
				an indication of usability.
		Quality		Required: Biometric images for
				various modalities are
				represented and exchanged as
				per the Image formats in MOSIP
				<u>Docs 1.1.15</u> .
				Recommended: Compliance to
				the image quality specifications
				(as applicable) in:
				a. ISO/IEC 29794-2:2017-
				Biometric Sample Quality
				(Finger Image Data)
				b.ISO/IEC 29794-6:2015-
				Biometric Sample Quality
				(Iris Image Data)
				c. ISO/IEC 29794-5:2010-
				Technical Report for
				Biometric Sample Quality
				(Face Image Data)
	Test Plan	Test plan :	structure	YES
	structure	follows		
		recomme	ndations in	
		Table 3		

Table 3 - Summary of recommendations for Test Plan structure

Item	Subheading	Description
Preface	Glossary	Terms, definitions, and abbreviations and
	Related Documents	related documents for referencing
		compliance
Introduction	Purpose, scope, users	Provide an overview the expected
	Applicable device profile	outcomes of the evaluation, a primer on
	Limitations	the test strategy and characteristics of
		the data that will be used in the
		evaluation.
Test Strategy	Data collection	The test strategy will provide the
	Execution	background to the system under test

Item	Subheading	Description
	Reporting	and the approach taken for testing. This will identify the incoming requirements to achieve the testing objectives and the expected outputs based on limitations identified.
Data privacy and management	PII Handling SOP and privacy policy	Handling of PII utilised for the evaluation
System overview	System Under Test	Description of the system under test. The system under test demonstrates compliance to the specifications discussed in Deviations must be included in the final test report, along with a reasonable justification. Comments from WG on Device Profile for face modality. "Some of this should be informed by ISO/IEC 24358 – Face-aware capture subsystem specifications"
		NOTE: It is key to note that in real-world laboratory testing, a device profile approach for various deployment use cases is proposed. These device profiles will be included over time in the framework itself and informed by the exploratory testing undertaken on various device types to have requirements in relation to number of people, environmental conditions etc. Table 2 Summary of
		recommendations for test plan preparation
Data	Dataset Preparation Datasets Naming convention Suitability	Description of the dataset used in the testing; attributes of the test data based on the requirements established. Planned data to demonstrate compliance to specifications discussed in Table 2

Item	Subheading	Description
Pre- testing	Pre-test readiness review	Pre-testing and set up description to
		ensure correct system operation and
		configuration
Test Method	Calculation of metrics	Test method to measure metrics to demonstrate compliance to specifications discussed in Deviations must be included in the final test report, along with a reasonable justification. Comments from WG on Device Profile
		for face modality.
		"Some of this should
		be informed by
		ISO/IEC 24358 –
		Face-aware capture
		subsystem
		specifications"
		NOTE: It is key to note that in real-world
		laboratory testing, a device profile
		approach for various deployment use
		cases is proposed. These device profiles
		will be included over time in the
		framework itself and informed by the
		exploratory testing undertaken on
		various device types to have
		requirements in relation to number of
		people, environmental conditions etc.
		Table 2 Summary of
		recommendations for test plan
		preparation
Test Cases	Test Case Setup Unconstrained Testing	Individual test cases to measure the system performance

3.3. Reporting the Results

Table below provides a summary of guidance and recommendations for test report produced as a result of MACP evaluation.

The guidance and recommendations herein are in accordance with various ISO/IEC 19795 series standards for testing and reporting.

Deviations can be made in depending on the type of evaluation and the modality used, with legitimate explanation for deviation is provided in the test report.

Table 4 - Recommendations on reporting the results

Item	Subheading	Description
Preface	Glossary	Terms, definitions, and abbreviations and
	Related Documents	related documents for referencing
	Notices	compliance
Introduction	Purpose, scope, users	Provide an overview the expected
	Limitations	outcomes of the evaluation, a primer on
		the test strategy and characteristics of
		the data that will be used in the
		evaluation.
Scenario	Device Profile Utilised	Evaluator references the device profile
description		used
	System Under Test	Description of system under test,
	Definition of Test Criteria	summary of operating environment,
	Concept of Operations	summary of pretesting activities for set
	System Information	up, additional information concerning
	Configuration audits	continual audit checks of the system
	Test observation and	configuration, expected outputs.
	problem log, Test log	The goal of test will be to evaluate
	Expected outputs	performance within the concept of
		operations, hence it should be designed
		and executed so that it mimics the
		functional and procedural aspects of
		such concept of operations.
		System information such as
		manufacturer, model, version, and
		firmware as applicable must be reported.
		A chronological record of the test events
		should also be covered by this report.
Data	Characteristics of Data	The test report should document
	Data Collection	whether the data utilised meets the
	Pretesting with data and	requirements of the MACP testing.
	final test data for analysis	Examples of data collection may be
		provided in the form of spreadsheets and
D. 6.		logs
Performance	Interim Analysis Results	Evaluator provides basis and narrative for
Results		management of interim analysis.

Item	Subheading	Description
Note: benchmarks	Final Analysis Results	For the final analysis, the performance
will be		results are reported in accordance with
determined	Overall assessment of the	the recommendations in Table 1
based on	biometric device tested	
modality and	Conformance to the test	
feedback based	plan	
on exploratory	pian	
evaluations to set		
the baseline		
Test Cases	Detailed test results for the	The test cases planned and executed for
	test cases	MACP compliance may be informed by:
		NIST Fingerprint Image Quality
	Summary of test results,	(NFIQ) Compliance for
	findings, and	fingerprint
	recommendations	IREX II for iris
		• ISO/IEC 29794-5 (WD) which
		establishes requirements for face
		image quality based on ISO/IEC
		39794-5 standard for face
		modality.
		The test cases must be planned and
		executed in the manner which ensures
		verification of biometric device
		performance against the specific
		requirements listed in Table 1
Deviations and	Deviations from the test	Explanations associated with any
exclusions	cases/procedures	deviations made from the planned test
		cases or the requirements of this
		compliance framework must be
		provided in the test report.
Full Test Plan		As per Table 2 and Table 3