Arkadelphia Public Schools
Director of Support Services
Jimmy King

## March Maintenance Report

- A breaker went out at AHS resulting in no heat or air in the old part of the building. This has been temporarily fixed. The parts are old and not easily replaced. A replacement breaker has finally been located. Carrier will install the new breaker after they receive it.
- Heat and air has been installed in the field house dressing rooms.
- Installation of LED lighting in the field house dressing rooms has begun.
- General routine maintenance tasks completed.

P.O. Box 10
Arkadelphia, AR 71923
870-246-5563