

## **Lead Testing Final Report**

For test points at or above 5 ppb lead content, per §160.077, secure water and discontinue use until remediated unless testing proves that flushing will provide water below 5ppb.

58 Test points were identified:

The 19 points listed in the table below indicated greater than 5parts per billion during the initial draw sampling phase.

12 outlets have signage placed to indicate "Hand Wash Only"

7 Outlets were successfully remediated through replacement, filtration or repair.

If you desire further health information, you can contact your county health department:

## monroecountyhealth.com

Monroe County Health Department 310 Market St, Paris, MO 65275 (660) 327-4259

Lab results are available on the school website.

Initial	Flush	Remedial	Location	Remediation Recommendations
6.32	1.56	2.06	Hand sink in room 25	Successfully Remediated
5.22	1.54	*	1st RR sink girls rr across from room 16	Signage in place
5.59	1.28	*	2nd RR sink girls rr across from room 16	
23.2	5.05	3.5	Hand sink in room 27	Successfully Remediated
6.88	3.26	3.5	1st RR sink in boys rr -Café	
9.12	4.02	3.68	2nd RR sink in boys rr -Café	
7.22	2.93	3.06	1st RR sink in girls rr -Café	
8.76	3.4	2.96	2nd RR sink in girls -Café	
5.11	3.71	*	Hand sink girls locker room 11	Signage in place
6.56	2.55	*	hand sink boys locker room 14	
19	1.98	*	1st Sink in boys RR across from room 36	
22.7	1.86	*	2nd Sink in boys RR across from room 36	
18.3	2.13	17	Hand sink in room 37	
8.52	1.28	*	1st Sink in girls RR across from room 38	
8.15	1.33	*	2nd Sink in girls RR across from room 38	
8.19	ND	*	Sink in boys RR in teacher workroom 39	
5.58	ND	*	Sink in girls RR in teacher workroom 39	
11.6	2.28	10.5	Sink in teacher workroom 39	
9.14	22.4	17.7	HB hydrant in concession stand	Successfully Remediated

The next full round of testing will be in the 28/29 school year.

Ph: 417-294-6112 Email: bobfranklin@gettheleadoutmo.us