

SECTION 08 33 00
SIDE COILING PERFORATED SERVICE DOORS

PART 1 GENERAL

1.01 GENERAL REQUIREMENTS

- A. Provide all materials, labor, equipment and services necessary to furnish, deliver and install all work under this section as shown on the contract documents, specified herein, and as specified by the job conditions.

1.02 DESCRIPTION

- A. Related work specified elsewhere:
 - 1. Metal Fabrication. Section 05 50 00
 - 2. Rough Carpentry. Section 06 10 00
 - 3. Access Panels & Doors: Section 08 31 00
 - 4. Painting: Section 09 91 00
 - 5. Electrical: Division 26

1.03 SUBMITTALS

- A. Procedures: Furnish submittals in accordance with the general requirements specified.
- B. Shop Drawing: Furnish shop drawings for architect's approval. Include elevations, sections, and details indicating dimensions, materials, finishes, conditions for anchorage and support of each side coiling door.
- C. Product Literature: Submit manufacturer's technical literature describing the product to be used under this section.
- D. Maintenance and Operating Manuals: Furnish complete manuals describing the materials, devices and procedures to be followed in operating and maintaining all side coiling doors under this section. Include manufacturer's brochures and parts lists describing the actual materials used in the product.

1.04 QUALITY ASSURANCE

- A. Regulatory Requirements: Comply with applicable requirements of the laws, codes, ordinances and regulations of federal, state and municipal authorities having jurisdiction.
- B. Manufacturer Requirements: Side coiling door manufacturer shall have been in the business of and have experience in manufacturing the type of product covered under this specification section as well as giving credible service for a minimum of five (5) years. Provide list of at least ten (10) completed projects which include the products covered under this section.

1.05 DELIVERY, STORAGE AND HANDLING

- A. General: Deliver and store materials in manufacturer's original packaging, labeled to show name, brand and type. Store materials in a protected dry location off the ground in accordance with manufacturer's instructions.

1.06 WARRANTY

- A. Side Coiling Door Warranty: Provide Two (2) Year Warranty signed by the manufacturer and installer agreeing to repair or replace work which has failed as a result of defects in materials or workmanship. Upon notification within the warranty period, such defects shall be repaired at no cost to the owner.

PART 2 PRODUCTS

SECTION 08 33 00
SIDE COILING PERFORATED SERVICE DOORS

2.01 SIDE COILING SERVICE DOORS

- A. Manufacturer: Side coiling perforated service doors shall be the model SC3000PF-A as manufactured by McKEON.

2.02 MATERIALS

- A. General: Each unit shall consist of an interlocking slat curtain designed to travel in a horizontal plane, smoothly and without binding. Curtain shall be driven to the open and close position by a positive action sprocket drive, without the use of cables or counterbalance weights.
 - 1. Curtain: Shall be fabricated of interlocking, perforated aluminum interlocking slats with an approximate cross section not less than 3" wide by 7/8" deep.
- B. Leading Edge: Curtain shall be furnished with an extruded aluminum member of tubular design to provide stiffness, limit deflection and provide for a tight fitting closure.
- C. Receiving Edge: Shall be fabricated of an extruded aluminum member with sufficient depth, designed to accept the leading edge and form a tight fitting closure when the door is the fully closed position.
- D. Head Track: Shall be of not less than 1/8" thick steel and shall be provided with an integral locking bar. The faying surface shall not be less than 38% of the flat plate area when the side coiling door is in the closed position. Locking bar shall lock and retain the coiling curtain in place.
- E. Floor Track (Optional): Shall be no greater than 1½" deep and include integral removable stainless steel protective cover plates to allow for easy cleaning and proper maintenance.
- F. Counterbalance Assemblies: The side coiling door shall be counterbalanced by means of adjustable steel helical torsion springs attached to shaft enclosed in pipe with required mounting blocks for attachment of curtain. Torsion springs shall be anchored to the same shaft and held in position by the same adjusting wheel accessible from outside the barrel assemblies.
- G. Coil Box: Shall be provided to entirely enclose coiled curtain and counterbalance assemblies. Coil box cover shall be of a rectangular design fabricated of 22 gauge G90 galvanized sheet steel.
- H. Electric Motor Operator: Side coiling door shall be provided with a compact power unit designed and built by the side coiling door manufacturer. Operator shall be equipped with an adjustable screw-type limit switch to break the circuit at termination of travel. High efficiency gearing running in an oil bath, shall be furnished together with a magnetic operated brake, completely housed to protect against damage, dust and moisture. An efficient overload protection device, which will break the power circuit and protect against damage to the motor windings shall be integral with the unit. Operator is to be housed in a NEMA type 1 enclosure.
 - 1. Motor: Shall be intermediate duty, thermally protected, ball bearing type with a class A or better insulation. Horsepower of motor is to be 1/3hp minimum or of manufacturer's recommended size, which ever is greater.
 - 2. Starter: Shall be size "0" magnetic reversing starter, across the line type with mechanical and electrical interlocks, with 10 amp continuous rating and 24 volt control circuit.
 - 3. Reducer: Spiral gear type, 70% efficiency minimum.
 - 4. Brake: Magnetically activated, integral within the operator's housing.
 - 5. Control Station: Provide flush mount key switch control station marked open, close and stop.
- I. Obstruction Sensing Device: The side coiling door shall be designed with a radio activated obstruction sensing safety edge. In the event that the safety edge meets an obstruction during the normal closing operation, the side coiling door shall stop, reverse and return to the open position.

SECTION 08 33 00
SIDE COILING PERFORATED SERVICE DOORS

- J. Finish: After completion of fabrication, clean all metal surfaces to remove dirt and chemically treat to provide for paint adhesion. All steel components shall receive a coat of prime paint finish and all exposed aluminum shall be of a clear anodized finish.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Examine surfaces and field conditions to which this work is to be performed and notify architect if conditions of surfaces exist which are detrimental to proper installation and timely completion of work.
- B. Verify all dimensions taken at job site affecting the work. Notify the architect in any instance where dimensions vary.
- C. Coordinate and schedule work under this section with work of other sections so as not to delay job progress.

3.02 INSTALLATION

- A. Perform installation using only factory approved and certified representatives of the side coiling door manufacturer.
- B. Install side coiling door assemblies at locations shown in perfect alignment and elevation, plumb, level, straight and true.
- C. Adjust side coiling door installation to provide uniform clearances and smooth non-binding operation.
- D. Install wiring in accordance with applicable local codes and the National Electrical Code Standard. Materials shall be UL listed.

3.03 PROTECTION AND CLEANING

- A. Protect installed work using adequate and suitable means during and after installation until accepted by owner.
- B. Remove, repair or replace materials which have been damaged in any way.
- C. Clean surfaces of grime and dirt using acceptable and recommended means and methods.