	WEEKLY DB's INSPECTION CHECKLIST			Page **1** of **2**
	Company Doc. No. HSEDOCS-WIC-00-000	**Contractor Ref. No.** QHSE- WIC-0000	**Date** 00-00-0000	**Revision** 00

Project Name & No:	
DB No:	

S.No	Check items	Yes	No	N/A
1	Firm base with grouting & easily accessible panel (height of leg is equal to 1m)	☐	☐	☐
2	The wiring & connections of DB are weatherproof	☐	☐	☐
3	Authorized operator name contact no. on DB panel	☐	☐	☐
4	Visualization of voltage, current, and type of tools to be used in the socket and panel	☐	☐	☐
5	Identification of input and output	☐	☐	☐
6	Confirmation of LOTO availability	☐	☐	☐
7	Cautionary safety signage labeled	☐	☐	☐
8	RCDs / ELCB with tripping of 30mA & in working condition	☐	☐	☐
9	Covers and locks are installed	☐	☐	☐
10	Condition of cable, power socket, and plug without damage	☐	☐	☐
11	Color coding to be followed for all cables/wires	☐	☐	☐
12	The plug socket should be an industrial-type	☐	☐	☐

Inspected By:

Name:

Designation

Date:

signature: