



# WEEKLY DB's INSPECTION CHECKLIST

Company Doc. No.  
HSEDOCS-WIC-00-000

Contractor Ref. No.  
QHSE-WIC-0000

Date  
00-00-0000

Revision  
00

Project Name & No:

DB No:

S.No	Check items	Yes	No	N/A
1	Firm base with grouting & easily accessible panel (height of leg is equal to 1m)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	The wiring & connections of DB are weatherproof	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Authorized operator name contact no. on DB panel	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Visualization of voltage, current, and type of tools to be used in the socket and panel	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	Identification of input and output	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Confirmation of LOTO availability	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	Cautionary safety signage labeled	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8	RCDs / ELCB with tripping of 30mA & in working condition	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9	Covers and locks are installed	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10	Condition of cable, power socket, and plug without damage	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11	Color coding to be followed for all cables/wires	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12	The plug socket should be an industrial-type	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

## Inspected By:

Name:

Designation

Date:

signature:



## WEEKLY DB's INSPECTION CHECKLIST

Page 2 of 2

**Company Doc. No.**  
HSEDOCS-WIC-00-000

**Contractor Ref. No.**  
QHSE- WIC-0000

**Date**  
00-00-0000

**Revision**  
00

