

Village of
Rushsylvania
Drinking Water
Consumer
Confidence
Report For 2023

The Village of Rushsylvania has prepared the following report to provide information to you, the consumer, on the quality of our drinking water. Included within this report is general health information, water quality test results, how to participate in decisions concerning your drinking water and water system contacts.

The Village of Rushsylvania receives its drinking water from two source wells on site at water plant. Rushsylvania treats your water using disinfection which involves the addition of chlorine to kill dangerous bacteria and microorganisms that may be in the water.

Ohio EPA completed a study of Rushsylvania's source of drinking water to identify potential contaminant sources and provide guidance on protecting the water source. According to the study, the aquifer that supplies water to the Village of Rushsylvania has a moderate susceptibility to contamination based on the presence of a relatively thick layer of clay overlaying the aquifer and there is no evidence to suggest ground water has been impacted by any significant levels of contaminants from human activities.

Copies of the source water assessment report prepared for The Village of Rushsylvania are available by contacting the Water plant @ 937-468-7014.

What are sources of contamination to drinking water?

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or human activity.

Contaminants that may be present in source water include: (A) Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife; (B) Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming; (C) Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses; (D) Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems; (E) Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, USEPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Federal Environmental Protection Agency's Safe Drinking Water Hotline (1-800-426-4791).

Who needs to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons, such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infection. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

About your drinking water.

The EPA requires regular sampling to ensure drinking water safety. The Village of Rushsylvania conducted sampling for bacteria, radiological, and disinfection by-products during 2023. Samples were collected for a total of 22 different contaminants most of which were not detected in the Village of Rushsylvania water supply. The Ohio EPA requires us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though accurate, are more than one year old.

Table of Detected Contaminants

Listed below is information on those contaminants that were found in the Village of Rushsylvania water Samples.

TABLE OF DETECTED CONTAMINANTS

Contaminants (Units)	MCLG	MCL	Level Found	Range of Detections	Violation	Sample Year	Typical Source of Contaminants
Radioactive Contaminants							
Gross Alpha	0	15	Non-detected	N/A	No	2023	Occurs naturally in some ground water ,major sources are soil and cigarettes.
Inorganic Contaminants							
Flouride	4	4	1.19	N/A	No	2017	Erosion of natural deposits, discharge from fertilizers,aluminum factories
Barium	2	2	.026	N/A	No	2017	Drilling wastes,discharge from metal refineries,natural deposits
Synthetic Organic Contaminants including Pesticides and Herbicides							
None detected						2023	
Volatile Organic Contaminants							
None detected						2023	
Residual Disinfectants							
Total Chlorine	4	4	0.81	0.3-1.9	No	2023	Water additive used to control microbes

Lead and Copper							
Contaminant (units)	Action Level (AL)	MCLG	Individual Results over the AL	90% of test levels were less than	Violation	Year Sampled	Typical source of Contaminants
Lead (ppb)	15 ppb	0 ppb	N/A	5.0ppb	No	2023	Corrosion of household plumbing, natural deposits
	0 out of 10 samples were found to have lead levels in excess of the lead action level of 15 ppb.						
Copper (ppm)	1.3 ppm	1.3 ppm	N/A	.05ppm	No	2023	Corrosion of household plumbing, natural deposits
	0 out of 10 samples were found to have copper levels in excess of the copper action level of 1.3 ppm.						

Lead Educational Information

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Village of Rushsylvania is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at 800-426-4791 or at <http://www.epa.gov/safewater/lead>.

Public Participation and Contact Information

How do I participate in decisions concerning my drinking water?

Public participation and comment are encouraged at regular meetings of Rushsylvania Board of Public affairs which meets on the first Monday of every month.

For more information on your drinking water contact Chris Coak @ 937-468-7014

Definitions of some terms contained within this report.

- Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Definitions Required if term is used within the CCR. (Required if applicable)

- Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- Maximum Residual Disinfectant Level Goal (MRDLG): The level of drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.
- Contact Time (CT) means the mathematical product of a “residual disinfectant concentration” (C), which is determined before or at the first customer, and the corresponding “disinfectant contact

time" (T).

- Microcystins: Liver toxins produced by a number of cyanobacteria. Total microcystins are the sum of all the variants/congeners (forms) of the cyanotoxin microcystin.
- Cyanobacteria: Photosynthesizing bacteria, also called blue-green algae, which naturally occur in marine and freshwater ecosystems, and may produce cyanotoxins, which at sufficiently high concentrations can pose a risk to public health.
- Cyanotoxin: Toxin produced by cyanobacteria. These toxins include liver toxins, nerve toxins, and skin toxins. Also sometimes referred to as "algal toxin".
- Level 1 Assessment is a study of the water system to identify the potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
- Level 2 Assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
- PFAS: Per- and polyfluoroalkyl substances (PFAS) are a group of man-made chemicals applied to many industrial, commercial and consumer products to make them waterproof, stain resistant, or nonstick. PFAS are also used in products like cosmetics, fast food packaging, and a type of firefighting foam called aqueous film forming foam (AFFF) which are used mainly on large spills of flammable liquids, such as jet fuel. PFAS are classified as contaminants of emerging concern, meaning that research into the harm they may cause to human health is still ongoing.
- Master Meter (MM): A master meter is one that connects a wholesale public water system to consecutive public water system(s). This type of meter monitors the amount of water being sent to the consecutive system(s) and can also be used to determine the quality of water being delivered to the consecutive system(s).
- Parts per Million (ppm) or Milligrams per Liter (mg/L) are units of measure for concentration of a contaminant. A part per million corresponds to one second in a little over 11.5 days.
- Parts per Billion (ppb) or Micrograms per Liter (µg/L) are units of measure for concentration of a contaminant. A part per billion corresponds to one second in 31.7 years.
- The "<" symbol: A symbol which means less than. A result of <5 means that the lowest level that could be detected was 5 and the contaminant in that sample was not detected.
- Picocuries per liter (pCi/L): A common measure of radioactivity.