Building Fire Prevention Inspection Checklist

Issue: June 26, 2017

Tip: To use this document, click **File** > **Make a Copy** and save to your Drive.

Evacuation Route

- ☐ Exits
- ☐ Aisles/Corridors
- ☐ Stairways
- ☐ Sprinkler Systems
- ☐ Manual Pull Stations
- ☐ Fire Lanes
- ☐ Fire Extinguishers
- ☐ Mechanical Rooms

Fire Safety Equipment and Standard

- ☐ Fire Walls/Partitions – Continuity/penetrations that require fire-stop
- ☐ Fire Doors – Proper operation
- ☐ Emergency Lighting – Functional
- ☐ Exit Signage – Locations and proper illumination
- ☐ Sprinkler Systems – General condition, storage not within 18 inches of heads
- ☐ Spare Sprinkler Heads – Spare head available on the premises
- ☐ Fire Pump – General Condition, pump controller in “on” position
- ☐ Fire Alarm System – Operational, “System Normal” indication
- ☐ Smoke/Heat Detection – None missing/bagged
- ☐ Special Hazards Fire Protection – (C02, Halon, FM 200) – Inspection current
- ☐ Sprinkler Control Valves – Locked open/supervised
- ☐ Fire Department Connection – Accessibility
- ☐ Roof Access – Hatches/Doors secured

Equipment and Standard

- ☐ Extension Cords – Proper use
- ☐ Hood/Duct Suppression – Properly serviced, UL 300 Standard, if applicable Flammable/Combustible Liquids – Properly Stored (Approved cabinets.)
- ☐ Space Heaters – Away from combustible materials, unplugged when not in use.
- ☐ Compressed Gas Cylinders – Properly secured.
- ☐ Open Flames – None present

Other

- ☐ As required by applicable code/standard.