



Firefighting Diesel Tank Monthly PPM Checklist

General Checklist				
1.	Check the overall condition of the firefighting diesel tank for any signs of damage or corrosion.	<input type="checkbox"/>	<input type="checkbox"/>	
2.	Inspect the tank area for any signs of leaks or spills.	<input type="checkbox"/>	<input type="checkbox"/>	
3.	Ensure that the tank's access points are secure and functioning properly.	<input type="checkbox"/>	<input type="checkbox"/>	
4.	Verify the presence and readability of the tank's labels and safety instructions.	<input type="checkbox"/>	<input type="checkbox"/>	
5.	Check the firefighting equipment connected to the tank for any visible signs of wear or damage.	<input type="checkbox"/>	<input type="checkbox"/>	
Diesel Tank Components Checklist:				
1.	Inspect the diesel tank for any signs of rust, corrosion, or other forms of damage.	<input type="checkbox"/>	<input type="checkbox"/>	
2.	Check the tank's fuel level and ensure it is within the acceptable range.	<input type="checkbox"/>	<input type="checkbox"/>	
3.	Verify the integrity of the tank's vents, valves, and pipes. Look for any signs of blockages or leaks.	<input type="checkbox"/>	<input type="checkbox"/>	
4.	Test the functionality of the tank's emergency shut-off valves.	<input type="checkbox"/>	<input type="checkbox"/>	
5.	Ensure the cleanliness of the tank's exterior and interior surfaces.	<input type="checkbox"/>	<input type="checkbox"/>	
Firefighting Equipment Checklist:				
1.	Inspect the condition of the firefighting hoses, nozzles, and valves for any signs of wear or damage.	<input type="checkbox"/>	<input type="checkbox"/>	
2.	Test the functionality of the firefighting pump and ensure it is operating smoothly.	<input type="checkbox"/>	<input type="checkbox"/>	
3.	Check the pressure gauges and meters to verify that they are providing accurate readings.	<input type="checkbox"/>	<input type="checkbox"/>	
4.	Inspect the condition of any fire suppression agents or chemicals stored alongside the tank.	<input type="checkbox"/>	<input type="checkbox"/>	
Safety Checklist:				
5.	Verify the presence and functionality of the tank's fire extinguishers and other safety equipment in the vicinity.	<input type="checkbox"/>	<input type="checkbox"/>	
6.	Check that safety signs and warnings are prominently displayed and easily visible.	<input type="checkbox"/>	<input type="checkbox"/>	
7.	Ensure that the area surrounding the tank is clear of any obstacles or potential hazards.	<input type="checkbox"/>	<input type="checkbox"/>	



Firefighting Diesel Tank Monthly PPM Checklist

Checked by: _____

Date: _____

