

Network Modernizations 2016 - Q&A



Question (submitted by vendors before noon, 12/28/2015)	Answer
Are there any as-built drawings for the cabling pathways in all schools?	There are no drawings for current cable pathways.
Will the added electrical outlet for Showalter MS need to be a dedicated circuit or just tie into the nearest circuit?	To the nearest circuit.
Will the cabling runs in open areas (i.e. Gym at Foster HS) need to be in conduit or can it be run "open" in J-hooks?	In the Foster Gym cables go through corner and then up to the trusses. J-hooks OK.