

TABLE OF CONTENTS

1	PUMP SELECTION	2
1.1	Chilled Water Pump Selection	2
1.1.1	Primary Chilled Water Pump for EC 1UP- EC 7 UP at 2586 RT (PCHP 1-7)	2
1.1.2	Secondary Chilled Water Pump for 4,886 RT (SCHP 1~3)	3
1.1.3	Secondary Chilled Water Pump for 9,772 RT (SCHP 4~6)	4
1.2	Cooling Water Pump Selection	5
1.2.1	Cooling Water Pump for EC 1DN – EC 7DN (CWP 1-7)	5
1.3	Make - Up Water Pump Selection	6
1.3.1	Make- Up Water Pump for Chilled Water	6
1.3.1.1	Pressurization Pump for Chilled Water (PPchw 1- 2)	6
1.3.1.2	Make- Up Water Pump for Chilled Water	7
1.3.2	Make-up Water Pump for Cooling Water Tower	8
2	CHILLED WATER PRESSURE TANK CALCULATION	9
2.1	Determining Water Volume, V_w and Residual Volume, V_{w1} , Height	9
2.1.1	Expansion of chilled water, R_{normal} ,	9
2.1.2	Maximum expansion rate of chilled water, R_{max} ,	11
2.1.3	Make-Up Water Flow Rate	11
2.1.4	Total Variation of Flow Rate	11
2.1.5	Water Height, H_w	12
2.2	Determining Gas Volume, V_g	13
2.3	Determining Total Volume of Expansion Tank, V_t	13
2.4	Determining Pressure Variation	14



1. PUMP SELECTION

1.1 Chilled Water Pump Selection

1.1.1 Primary Chilled Water Pump for EC 1UP- EC 12 UP and EC 1DN- EC 12 DN at 5000 RT (PCHP 1-12)

(a) Flow Rate Calculation

(i) Stage 1 Operation

Flow Rate Calculation:

Cooling Capacity

Differential Temp of Chilled Water

Flow Rate:

$$\frac{15120 \text{ Mcal/h}}{1.0 \text{ Mcal / m}^3 \cdot ^\circ\text{C} \times 10 ^\circ\text{C}}$$

Selected: 1512 m³/h.

$$\begin{aligned} &= 5000 \text{ RT} \times 3.024 \text{ Mcal/h} \cdot \text{RT} = 15120 \text{ Mcal/h} \\ &= 14.44^\circ\text{C} - 4.44^\circ\text{C} = 10 ^\circ\text{C} \end{aligned}$$

$$\begin{aligned} Q &= m \cdot c_p \cdot \Delta T \\ m &= \rho \cdot V \\ V &= Q / [(\rho \cdot c_p) \cdot \Delta T] \end{aligned}$$

Specific Density = $\rho \cdot C_p$

CONVE
RSION

= 1512 m³/h

(b) Pump head

Pipe, Fittings, Valves

8 mAq

Safety Factor (10%)

0.8 mAq

Control Valves (FCV)

3 mAq

Y- Strainer

3 mAq

Air Separator

1.5 mAq

Equipment Pressure Drop

Cooling Tower

0 mAq

Chiller

7 mAq

TES

0 mAq

HEX

0 mAq

TOTAL

23.3 mAq

SELECTED

24 mAq

Estimation

(c) Specification

Item	Description
EQUIPMENT NO.	PCHP – 1– 12

**Will BE
SELECTED
AND
LISTED IN**



SHINRYO CORPORATION

SCHEDULE

TYPE	Horizontal Split Case Pump					
SPECIFICATION	1,512 m ³ /h x 24 mAq x 160 kW					
MOTOR	3ø x 415V					
SHAFT SEAL	Mechanical Seal					
QUANTITY	Phase 1					
	12					



Specified in Equip. Schedule.
Or calculated from the total
chillers capacity by the
numbers of pumps.

1.1.2 **Secondary Chilled Water Pump** for **4,886 RT (SCHP 1~3)**

Not applicable to BURJ
DUBAI Project as the
secondary pumps are not
to supply to customer.
They to supply in plant
use.

(a) **Flow Rate Calculation**

$$\begin{aligned}
 \text{Capacity of pump} &= 4886 \text{ RT} \times 3.024 \text{ Mcal/h} \cdot \text{RT} = 14,775 \text{ Mcal/h} \\
 \text{Differential Temp. of Chilled Water} &= 14.0^\circ\text{C} - 5.0^\circ\text{C} = 9.0^\circ\text{C} \\
 \text{Flow Rate:} &= \frac{14,775 \text{ Mcal/h}}{1.0 \text{ Mcal} / \text{m}^3 \cdot ^\circ\text{C} \times 9.0^\circ\text{C}} = 1642 \text{ m}^3/\text{h} \\
 \text{Selected} &= 1642 \text{ m}^3/\text{h}
 \end{aligned}$$

(b) **Pump Head**

Pipe, Fittings, Valves	6 mAq
Safety Factor (10%)	0.6 mAq
Control Valves (FCV)	0 mAq
Y- Strainer	3 mAq
Distribution Losses	
Distribution Piping	25 mAq
Customer Station Piping	4 mAq
Y- Strainer	3 mAq
TCV	3 mAq
HEX	10 mAq
TOTAL	54.6 mAq
SELECTED	55 mAq

(c) **Specification**

Item	Description
EQUIPMENT NO.	SCHP 1-3
TYPE	Horizontal Split Case Pump
SPECIFICATION	1,642 m ³ /h x 55 mAq x 380 kW
MOTOR	3ø x 415V
SHAFT SEAL	Mechanical Seal
QUANTITY	Phase 1
	3



Specified in Equip.
Schedule. Or calculated
from the total chillers
capacity by the numbers
of pumps.

1.1.3 Secondary Chilled Water Pump for 9,772 RT (SCHP 4~6)

(a) Flow Rate Calculation

$$\begin{aligned}
 \text{Capacity of pump} &= 9772 \text{ RT} \times 3.024 \text{ Mcal/h} \cdot \text{RT} = 29,551 \text{ Mcal/h} \\
 \text{Differential Temp. of Chilled Water} &= 14.0^\circ\text{C} - 5.0^\circ\text{C} = 9.0^\circ\text{C} \\
 \text{Flow Rate:} &= \frac{29,551 \text{ Mcal/h}}{1.0 \text{ Mcal} / \text{m}^3 \cdot ^\circ\text{C} \times 9.0^\circ\text{C}} = \underline{\underline{3,284 \text{ m}^3/\text{h}}} \\
 \text{Selected} &= \underline{\underline{3,284 \text{ m}^3/\text{h}}}
 \end{aligned}$$

(b) Pump Head

Pipe, Fittings, Valves	6 mAq
Safety Factor (10%)	0.6 mAq
Control Valves (FCV)	0 mAq
Y- Strainer	3 mAq
Distribution Losses	
Distribution Piping	25 mAq
Customer Station Piping	4 mAq
Y- Strainer	3 mAq
TCV	3 mAq
HEX	10 mAq
TOTAL	54.6 mAq
SELECTED	55 mAq

(c) Specification

Item	Description					
EQUIPMENT NO.	SCHP- 4-6					
TYPE	Horizontal Split Case Pump					
SPECIFICATION	3,284 m³/h x 55 mAq x 750 kW					
MOTOR	3ø x 415V					
SHAFT SEAL	Mechanical Seal					
QUANTITY	Phase 1	Phase 2	Phase 3	Phase 4	Phase 5	Phase 6
	2	0	0	1	0	0



1.2 Cooling Water Pump Selection

1.2.1 Cooling Water Pump for EC 1 – EC 12 (CWP 1-12)

(a) Flow Rate Calculation

Flow Rate Calculation:

Cooling Capacity = 5000 RT x 3.024 Mcal/h · RT = 15,120 Mcal/h
Differential Temp of cooling Water 41.11°C – 33.33°C = 7.78°C

Flow Rate = $\frac{15120 \text{ Mcal/h} \times 1.2}{1.0 \text{ Mcal} / \text{m}^3 \cdot ^\circ\text{C} \times 7.78^\circ\text{C}}$ = 2,332 m³/h

Selected = 2332 m³/h

Chiller capacity

Estimated Evaporation loss in chiller's condenser. (20%)

b)

Pump Head

Pipe, Fittings, Valves	9 mAq
Safety Factor (10%)	0.9 mAq
Control Valves (XCV)	0 mAq
Y- Strainer	3 mAq
Equipment Pressure Drop	
Cooling Tower	7 mAq
Chiller	8 mAq
TES	0 mAq
HEX	0 mAq
TOTAL	27.9 mAq
SELECTED	30 mAq

c) Specification

Item	Description
EQUIPMENT NO.	CWP 1-12
TYPE	Horizontal Split Case Pump
SPECIFICATION	2,332 m ³ /h x 30 mAq x 280 kW
MOTOR	3ø x 415V
SHAFT SEAL	Mechanical Seal
QUANTITY	Phase 1
	12



1.3 Make - Up Water Pump Selection

1.3.1 Make- Up Water Pump for Chilled Water

1.3.1.1 Pressurization Pump for Chilled Water (PPchw 1- 2)

(a) Capacity

Flow Rate per Chiller
Loss per Chiller

$$= 1,512 \text{ m}^3/\text{h per chiller}$$

$$= 0.05\% \times 1,512 \text{ m}^3/\text{h} = 0.756 \text{ m}^3/\text{h}$$

From primary chiller pump
calculated above

Loss percentage
given by
manufacturer

Total Chilled Water Loss = $0.756 \text{ m}^3/\text{h} \times 12 \text{ chillers} = 9.072 \text{ m}^3/\text{h}$
= **9.1 m³/h**

(b) Pump Head

Pipe, Fittings, Valves	7 mAq
Safety Factor (10%)	0.7 mAq
Control Valves (LCV)	3 mAq
Y- Strainer	3 mAq
Equipment Pressure Drop	
System Pressure	30 mAq
Actual Valve	6 mAq
TES	0 mAq
HEX	0 mAq
TOTAL	49.7 mAq
SELECTED	55 mAq

(c) Capacity

Item	Description
EQUIPMENT NO.	PPchw 1-2 (1 standby)
TYPE	Vertical Multi Stage Pump
SPECIFICATION	9.1 m ³ /h x 55 mAq x 2.2 kW
MOTOR	3ø x 415V
SHAFT SEAL	Mechanical Seal
QUANTITY	Phase 1
	2



1.3.1.2 Make- Up Water Pump for Chilled Water

(a) Capacity

Considering Stable Condition:

Chilled Make- Up Water Flow Rate

$$= 9.1 \text{ m}^3/\text{h} \times 4$$

$$= \underline{36.4 \text{ m}^3/\text{h}}$$

Calculated
above

Sort of safety
factor for the
make up water
pumps

(b) Pump Head

Pipe, Fittings, Valves	7 mAq
Safety Factor (10%)	0.7 mAq
Control Valves (LCV)	3 mAq
Y- Strainer	3 mAq
Equipment Pressure Drop	
System Pressure	30 mAq
Actual Valve	6 mAq
TES	0 mAq
HEX	0 mAq
TOTAL	49.7 mAq
SELECTED	55 mAq

(c) Specification

Item	Description					
EQUIPMENT NO.	MPchw 1-3 (1 standby)					
TYPE	Vertical Multi Stage Pump					
SPECIFICATION	36.4 m³/h x 55 mAq x 11 kW					
MOTOR	3ø x 415V					
SHAFT SEAL	Mechanical Seal					
QUANTITY	Phase 1	Phase 2	Phase 3	Phase 4	Phase 5	Phase 6
	3	0	0	0	0	0



1.3.2 Make-up Water Pump for Cooling Water Tower

(a) Capacity

Flow rate of Cooling Tower 1
Differential Temp of Cooled Water

= 2,332 m³/h per tower
= 7.78 °C

Evaporative Loss per tower
Drift Loss per tower
Concentration Cycle
Blow Down Loss per tower

= 1.3% x 2332 m³/h = 30.3 m³/h
= 0.005% x 2332 m³/h = 0.12 m³/h
= 6

= $\frac{\text{Evaporative Loss}}{(\text{Concentration cycle} - 1)} - \text{Drift Loss} = 4.21 \text{ m}^3/\text{h}$

Total Loss per tower

= 36.36 m³/h (1.56%) loss

Total Cooling Tower Water Loss

= 36.36 m³/h x 12
= **436.32 m³/h loss**

From calculation
above for cooling
water pump

Evap & Drift & Blow
Down loss are
specified by
supplier

Formulation :
Concentration cycle =
Evap + Drift + Blow
Down loss
From ASHRAE
Handbook, chap S36

A total number of 2 pumps will be operating. Therefore, the required pump capacity:

Pump Capacity: = 436.32 m³/h / 2
≈ **218 m³/h**

(b) Pump Head

Pipe, Fittings, Valves	7 mAq
Safety Factor (10%)	0.7 mAq
Control Valves (Ball Float)	3 mAq
Y- Strainer	3 mAq
Equipment Pressure Drop	
Actual Head	17 mAq
FM Valve	0 mAq
TES	0 mAq
HEX	0 mAq
TOTAL	30.7 mAq
SELECTED	32 mAq

(c) Specification

Item	Description
EQUIPMENT NO.	MPcw 1-2 (one Stand by)
TYPE	Horizontal Split Case Pump
SPECIFICATION	218 m ³ /h x 32 mAq x 22 kW
MOTOR	3ø x 415V
SHAFT SEAL	Mechanical Seal
QUANTITY	Phase 1
	2



1.4 Side Stream Filtration Unit Selection

1.4.1 Side Stream Filtration Unit for Cooling Tower (SSFU 1)

(a) Capacity

Total Flow Rate from Cooling Tower 1 – 4 = 4428 m³/h

Requires 2% of total cooling water flow rate = 2% x 4428 m³/h
= **88.56 m³/h**

Selected = 89 m³/h

NOT APPLICABLE
TO BURJ DUBAI
PROJECT

Extracted from
Woodlands Project

(b) Specification

27. Specification			
Item	Description		
EQUIPMENT NO.	SSFU 1		
TYPE	Centrifuge Filter Units		
SPECIFICATION	89 m³/h		
MOTOR	3ø x 415V x 15kW		
SHAFT SEAL	Mechanical Seal		
QUANTITY	Stage 1	Stage 2	Stage 3
	1	-	-

1.4.2 Side Stream Unit for Chilled Water (SSF-DCP-1-3)

(a) Capacity

Requires 1 turn per 5 days of total system volume

$$\Rightarrow \dot{Q} = 12,096 \text{ m}^3 \div 2 \text{ days} \div 24 \text{ hours}$$

$$\dot{Q} = 252 \text{ m}^3 / \text{h}$$

Selected = 252 m³/h

(b) Specification

Item	Description		
EQUIPMENT NO.	SSF-DSP- 1-3		
TYPE	Centrifuge Filter Units		
SPECIFICATION	252 m³/h		
MOTOR	3ø x 415V x 15kW		
SHAFT SEAL	Mechanical Seal		
QUANTITY	Stage 1		
	3		



1.5 Oil Pump Selection

1.5.1 Oil Pump for Gen- Set

NOT APPLICABLE
TO BURJ DUBAI
PROJECT.
Extracted from
Woodlands Project

(a) Flow Rate Calculation

¹Gen- Set oil consumption = 0.885 m³/h
Pump capacity is to cater for 2 Gen- sets.

Flow Rate:

$$0.885 \text{ m}^3/\text{h} \times 2 \times 10\% = 1.947 \text{ m}^3/\text{h}$$

Selected: 2.0 m³/h

(b) Pump head

Pipe, Valves, Fittings	5 mAq
Safety Factor (10%)	0.5 mAq
Y- Strainer	3 mAq
Actual Head	10 mAq
TOTAL	18.5 mAq

SELECTED 2.0 kgf/cm² G

(c) Specification

Item	Description		
EQUIPMENT NO.	OSP 1		
TYPE	Oil Gear Pump		
SPECIFICATION	2.0 m³/h x 2.0 kg f/cm² G x 0.75 kW		
MOTOR	3ø x 415V		
SHAFT SEAL	Mechanical Seal		
QUANTITY	Stage 1	Stage 2	Stage 3
	1	1	1

¹ KOHLER Power Systems Catalogue; Model 1000 ROZD



2. CHILLED WATER PRESSURE TANK CALCULATION

The total volume of an expansion tank, V_t is as follow:

$$V_t = V_g + V_w + V_{w1} \quad [m^3]$$

Where:

V_t : Total volume of the expansion tank, m^3

V_g : Gas Pressurizing volume, m^3

V_w : Water volume, m^3

V_{w1} : Residual volume, m^3

Assumptions:

- Conditions in calculating the following values are assumed to be at maximum conditions.
- Supply and return temperature at all times are assumed constant.
- $T_{supply} = 4.44^\circ C$; $T_{return} = 14.44^\circ C$
- Water temperature during start- up is $25^\circ C$

1.6 Determining Water Volume, V_w and Residual Volume, V_{w1} , Height

1.6.1 Expansion of chilled water, R_{normal} ,

$$R = \frac{\beta \times V \times H_m}{M} \quad [m^3 / hr]$$

Where:

R_{normal} : Expansion of chilled water at normal time, m^3 / hr

β_{normal} : Volumetric coefficient of thermal expansion of water, $^\circ C^{-1}$

V : Total volume of chilled water system, $m^3 \approx 12,100 m^3$

H_m : Maximum cooling load, Mcal/hr = 30,240 Mcal/hr (assume starting with 2 chiller)

M : Total system heat capacity, kcal/ $^\circ C$

Calculated by
(Pipe cross sect.
Area * Length)

for the whole
chilled water
system.

Chillers shall not be start up
simultaneously to avoid
sudden increase in electric
supply and the max.
expansion of water. (usually
2 by 2 until the water are
chilled to the steady supply
temp)



$$\beta_{normal} = \frac{\frac{1}{\rho_{ave}} - \frac{1}{\rho_{supply}}}{\frac{1}{\rho_{supply}} \times (T_{ave} - T_{supply})} \quad [^{\circ}C^{-1}]$$

Where:

T_{ave} : Average temperature of chilled water, $^{\circ}C$

T_{supply} : Supply temperature of chilled water, $^{\circ}C$

ρ_{ave} : Density of average temperature of chilled water, kg/m^3

ρ_{supply} : Density of supply temperature of chilled water, kg/m^3

Obtained from Heating, ventilating, and Air-conditioning analysis and design (Mcquiston) APPENDIX A

$$= 9.44^{\circ}C$$

$$= 4.44^{\circ}C$$

$$= 999.65 \text{ kg/m}^3$$

$$= 999.90 \text{ kg/m}^3$$

$$M = V \times 1000 \text{ kg/m}^3 \times 1.0 \text{ kcal/kg}^{\circ}C \times (1.2 \sim 1.5) \quad [kcal/^{\circ}C]$$

(20%-50% of the heat load in piping and equipment is assumed to be the total system heat capacity)

Where:

1000 kg/m^3 is density of water

1.0 $kcal/kg.^{\circ}C$ is specific heat capacity of water

$$\therefore M = 12,000 \text{ m}^3 \times 1000 \text{ kg/m}^3 \times 1.0 \text{ kcal/kg}^{\circ}C \times 1.5 \quad [kcal/^{\circ}C]$$

$$M = 18.0 \times 10^3 \quad \text{Mcal}/^{\circ}C$$

$$\Rightarrow \beta_{normal} = \frac{\frac{1}{999.65} - \frac{1}{999.9}}{\frac{1}{999.9} \times (9.44 - 4.44)} \quad [^{\circ}C^{-1}]$$

$$\beta_{normal} = 0.00005 \text{ }^{\circ}C^{-1}$$

$$R_{normal} = \frac{0.00005^{\circ}C^{-1} \times 12,000 \text{ m}^3 \times 30240 \text{ Mcal/hr}}{18.0 \times 10^3 \text{ Mcal}/^{\circ}C} \quad [m^3/hr]$$

$$R_{normal} = 1.0084 \text{ m}^3/hr$$



1.6.2 Maximum expansion rate of chilled water, $R_{\max}$,

$$T_{\text{ave}} = 14.72^{\circ}\text{C} ; \rho_{\text{ave}} = 999.09 \text{ kg} / \text{m}^3$$

$$\beta_{\max} = \frac{\frac{1}{999.09} - \frac{1}{999.9}}{\frac{1}{999.9} \times (14.72 - 5.0)} \quad [^{\circ}\text{C}^{-1}]$$

(CHW Temp Start up + CHW Temp Supply)

$$\beta_{\max} = 0.0000789^{\circ}\text{C}^{-1}$$

$$R_{\max} = \frac{0.0000789^{\circ}\text{C}^{-1} \times 12,000 \text{m}^3 \times 30,240 \text{Mcal} / \text{hr}}{18.0 \times 10^3 \text{Mcal} / ^{\circ}\text{C}} \quad [\text{m}^3 / \text{hr}]$$

$$R_{\max} = 1.59 \text{m}^3 / \text{hr}$$

1.6.3 Make-Up Water Flow Rate

Assumptions: Make- up water flow rate is at a steady flow rate, hourly, i.e 0.05% of total system flow rate

$$\dot{Q}_{\text{make-up}} = \frac{60,000 \text{RT} \times 3.024 \text{Mcal} / \text{hr} \cdot \text{RT} \times 0.0005}{10.0^{\circ}\text{C}} \quad [\text{m}^3 / \text{hr}]$$

Volume flow rate

Total Chillers capacity

Temp Diff. Between CHWS AND CHWR

$$\dot{Q}_{\text{make-up}} = 9.072 \text{m}^3 / \text{hr}$$

1.6.4 Total Variation of Flow Rate

Assumptions: Taking at maximum condition, i.e at start up:

$$\dot{Q}_{\text{var}} = R_{\max} + \dot{Q}_{\text{make-up}} \quad [\text{m}^3 / \text{hr}]$$

$$\dot{Q}_{\text{var}} = 1.59 + 9.072 \quad [\text{m}^3 / \text{hr}]$$

$$\dot{Q}_{\text{var}} = 10.66 \text{m}^3 / \text{hr}$$

$$q = m \cdot C_p \cdot \text{TD}$$

$$= Q \cdot \text{density} \cdot C_p \cdot \text{TD}$$

Density * Cp = 1.00 Mcal / °C

$$Q = \frac{(q \cdot \text{conversion factor} \cdot \text{normal})}{\text{TD}}$$

1.6.5 Water Height, H_w

Assumptions: Water volume, V_w to be **10-20** minutes of maximum total variation flow rate of chilled water. Additional **10%** allowance is considered for residual volume, V_{w1} .

$$V_w = \dot{Q}_{var} \times t_{storage} [m^3]$$

$$V_{w1} = V_w \times 0.1 [m^3]$$

$$H_w = \frac{4 \times (V_w + V_{w1})}{\pi \times D^2} [m]$$

Where:

H_w : Height of water side, m
 V_w : Water volume, m^3
 V_{w1} : Residual volume, m^3
 $t_{storage}$: Water storage time (10~20 minutes), taking 20 minutes
 D : Diameter of expansion tank, m

$$D = \sqrt{\frac{4 \times \dot{Q}_{var} \times t_1}{\pi \times H_{buffer}}} [m]$$

Where:

t_1 : Stability period, minute (2~3 minutes), taking **3 minutes**
 H_{buffer} : buffer zone for expansion and contraction (**0.1~0.15m**)

$$D = \sqrt{\frac{4 \times 7.42 m^3 / hr \times 0.05 hr}{\pi \times 0.15 m}} [m]$$

$$D = 2.13 m$$

$$\underline{D \approx 2.1 m}$$

$$\Rightarrow V_w = 10.66 m^3 / hr \times \frac{20}{60} hr [m^3]$$

$$\underline{V_w = 3.553 m^3}$$

$$\Rightarrow V_{w1} = 3.553 \times 0.1 [m^3]$$

$$\underline{V_{w1} = 0.3553 m^3}$$



$$\Rightarrow H_w = \frac{4 \times (3.553 + 0.3553)}{\pi \times 2.13^2} \quad [m]$$

$$\underline{H_w = 1.097 \text{ m}}$$

1.7 Determining Gas Volume, V_g

- GAS VOLUME, V_g

Assumptions: Assume that maximum variation volume is **2~3 minutes** of the total variation of chilled water flow rate, Q_{var} , taking into account stability period of distribution pumps.

$$V_g = \frac{\dot{Q}_{var} \times t_1}{\frac{\Delta P}{P}} \quad [m^3]$$

Where:

t_1 : Taking as 3 minutes

ΔP : Variation of gas- pressure during expansion, $\text{kgf/cm}^2 \text{ G}$

P : Initial gas pressure, $\text{kgf/cm}^2 \text{ G}$, taking **$P = 3.0 \text{ kgf/cm}^2$**

$\Delta P/P$: Variation of gas pressure during expansion is assumed to be 1~5% of the initial gas pressure. Normally is assumed to be **5% of the initial gas pressure.**

$$\Rightarrow V_g = \frac{10.66 \text{ m}^3 / \text{hr} \times 0.05 \text{ hr}}{\frac{0.15 \text{ kgf} / \text{cm}^2 \text{ G}}{3.0 \text{ kgf} / \text{cm}^2 \text{ G}}} \quad [m^3]$$

$$\underline{V_g = 10.66 \text{ m}^3}$$

- GAS HEIGHT

$$H_g = \frac{4 \times V_g}{\pi \times D^2} \quad [m]$$

$$\Rightarrow H_g = \frac{4 \times 10.66 \text{ m}^3}{\pi \times 2.13^2 \text{ m}^2} \quad [m]$$

$$\underline{H_g = 2.99 \text{ m}}$$

1.8 Determining Total Volume of Expansion Tank, V_t

- EXPANSION TANK HEIGHT, H_t

$$H_t = H_g + H_w \quad [m]$$



$$\Rightarrow H_t = 2.99 + 1.097 \quad [m]$$

$$H_t = 4.087 \text{ m}$$

$$\underline{H_t \approx 4.1m}$$

- EXPANSION TANK VOLUME, V_t

$$V_t = \frac{\pi \times D^2 \times H_t}{4} \quad [m^3]$$

$$\Rightarrow V_t = \frac{\pi \times 2.13^2 \times 4.1}{4} \quad [m^3]$$

$$V_t = 14.58 \text{ m}^3$$

$$\underline{V_t \approx 14.6 \text{ m}^3}$$

1.9 Determining Pressure Variation

$$PV^n = \text{Constant}$$

$$P_1 \times (V_{g1})^n = P_2 \times (V_{g1})^n$$

Where:

P_1 : Pressure during normal operation, kgf/cm²

P_2 : Pressure during expansion, kgf/cm²

n : 1.0 ~ 1.4 for nitrogen gas, taking $n = 1.4$.

Thus, pressure variation would be the difference between P_1 and P_2 .

Assumptions: V_{g1} is the gas volume minus the volume of the buffer zone for expansion and contraction.

V_{g1} has the following relationship:

$$V_{g1} = \frac{\pi \times D^2}{4} \times \left(H_g - \frac{H_{buffer}}{2} \right) \quad [m^3]$$

$$\Rightarrow V_{g1} = \frac{\pi \times 2.13^2}{4} \times \left(3.0 - \frac{0.15}{2} \right) \quad [m^3]$$

$$\underline{V_{g1} = 10.39 \text{ m}^3}$$

$$\Rightarrow 3.0 \times (10.66)^{1.4} = P_2 \times (10.39)^{1.4}$$

$$P_2 = 3.11 \text{ kgf / cm}^2$$



$$\therefore P_2 - P_1 = 0.11 \text{ kgf} / \text{cm}^2$$



Specification:

Item	Description					
EQUIPMENT NO.	PT-1					
TYPE	Steel Sheet Cylindrical Tank					
CONTENTS	Nitrogen					
CAPACITY	15 m ³					
DIMENSION	3,000Φ x 4,100 H					
PRESSURE	3.0 kgf/cm ² G (working) 8.0 kgf/cm ² G (max)					
QUANTITY	Phase 1					
	1					



3. Make- Up Water Tank (MWT 1 – 2)

(a) **Tank Volume Calculation**

Total make up water flow rate:

$$\begin{aligned}\text{Total Chilled Water Loss} &= 36.4 \text{ m}^3/\text{h} \\ \text{Total Cooling Water Loss} &= 415.56 \text{ m}^3/\text{h} \\ \text{Total Make- Up Water Loss} &= 451.96 \text{ m}^3/\text{h}\end{aligned}$$

Required Make-Up Tank holding capacity for 6 hours operation:

$$451.96 \text{ m}^3/\text{h} \times 6 \text{ hours} = 2711.76 \text{ m}^3$$

Selected Tank Capacity = 2712 m³

(b) **Specification:**

Item	Description		
EQUIPMENT NO.	MWT-1-2 (complete with internal partition)		
TYPE	Concrete water Tank		
EFFECTIVE CAPACITY	2712 m ³		
DIMENSION	24 mL x 25 mW x 5 mH		
QUANTITY	Stage 1	Stage 2	Stage 3
	2	-	-

