



**EMERGENCY MEDICAL
SERVICES AGENCY**
LOS ANGELES COUNTY

Healthcare Facility Emergency Power Resilience Playbook

Appendix Content

Hospitals in Los Angeles County are strongly encouraged to use this Emergency Power System Assessment and Benchmarking Worksheet to capture key details about their emergency power system's strengths and potential gaps. The Worksheet will also help hospitals compare their emergency power system capabilities and potential shortcomings against other hospitals in Los Angeles County using anonymized and aggregated benchmarking data. This Worksheet should be completed by the facility director or a qualified member of the engineering department. Hospitals can refer to the answers provided for the LAC EMS Agency's previous census of hospital emergency power systems to make completion of this Worksheet easier. NOTE: This worksheet is available as a downloadable Word file on the LAC EMS Agency's website.

Emergency Power System Assessment and Benchmarking Worksheet for Hospitals (To be completed by Facility Director or his or her staff)

Part I – Background Questions

Name of facility	
Address of facility	
Name, title, and contact information of the person completing the worksheet	
Number of licensed acute care beds	
The date worksheet was completed	

Appendix B - Emergency Power System Assessment and Benchmarking Worksheet for Hospitals

Part II – Vulnerability Assessment with Benchmarking Data and Suggested Mitigation Strategies to Address Vulnerabilities (To be completed by Facility Director or other qualified personnel.) Completed document can help guide the Emergency Power System Review discussion.

Section A – Hospital Benchmarking Data

Question	Answer	Benchmarking Data	Suggested Mitigation Strategies to Address Vulnerabilities
Number of generators		The average number of generators is 3.41	If your facility is operating with a single generator, you should seriously consider installing a quick-connect device to enable rapid connection of a temporary replacement generator. Since single-generator facilities have no redundant emergency power, the failure of their only generator and the inability to quickly connect a temporary replacement puts patients at greater risk of an emergency evacuation. (See Appendix I for additional information about quick-connect devices).
What is the ratio of total kW generator power to the number of licensed acute care beds in your facility? (Add up the kW power of each generator in the emergency power system and divide this figure by the total number of licensed acute care beds.) The LAC EMS Agency recognizes that the number of staffed beds in a hospital is often significantly lower than licensed beds. Since the number of staffed beds fluctuates, the number of licensed beds was used to determine the ratio of kW generator power.		The average amount of generator power measured in kW per acute care licensed bed is 11 kW. Among the hospitals included in the census, the lowest kW-to-bed ratio is 0.44 and the highest is 57.25. There is no federal or state standard for the kW-to-bed ratio. This figure is provided as a guide for hospitals in LAC.	If your hospital has less than 5 kW per bed, consideration should be given to expanding your emergency power system.

Part II Continued– Vulnerability Assessment with Benchmarking Data and Suggested Mitigation Strategies to Address Vulnerabilities (To be completed by Facility Director or other qualified personnel.) Completed document can help guide the Emergency Power System Review discussion.

Section A Continued – Hospital Benchmarking Data

Question	Answer	Benchmarking Data	Suggested Mitigation Strategies to Address Vulnerabilities
How old are your generators?		The average age of the 271 generators included in the LAC EMS Agency census is 24.6 years. The suggested useful life of a generator is 30 years, based on Roadmap to Resiliency , a white paper on emergency power resilience published in 2017 by the American Society for Healthcare Engineering and Powered for Patients.	Any facility with a generator 30 years of age or older should develop plans to replace the generator as soon as possible.
What is the emergency power system runtime based on your facility's onsite fuel storage capacity? See Generator Fuel Consumption Rate Chart in Appendix S		The average runtime among hospitals in LAC included in the census is 100.35 hours based on full tanks. 34 hospitals have more than 100 hours, and of these, 5 have in excess of 200 hours of runtime. 44 hospitals have less than 100 hours of runtime, of which 14 have less than 40 hours of runtime. Of these 14 hospitals, 4 have a runtime between 20 and 30 hours and 2 have a runtime below 20 hours.	The federal government has established 96 hours as the ideal time a hospital should be able to operate its emergency power system before refueling. Hospitals with less than 40 hours of emergency power runtime should ensure that they have a contract with a secondary fuel supplier. In addition, the facility should ensure that it can make an immediate payment to this secondary fuel supplier during a power outage to ensure timely fuel delivery, especially if this provider is a new vendor for the facility. These facilities should also consider expanding their existing fuel system's capacity.

Part II Continued— Vulnerability Assessment with Suggested Mitigation Strategies to Address Vulnerabilities. (To be completed by Facility Director or other qualified personnel.) Completed document can help guide the Emergency Power System Review discussion.

Question	Answer	Guidance and Suggested Mitigation Strategies to Address Vulnerabilities
Do you have a generator service contract in place?	Yes or No	If no, a service contract should be executed immediately with a reputable service provider. If yes, have these repairs or upgrades been scheduled? If not, address any impediments to scheduling suggested repairs or upgrades with facility management and the generator service provider. System review that is not their primary supplier. In these situations, service providers will not deliver fuel or decrease a contract for repairs or delivery. Facilities should be addressed by having a means to make immediate payment for fuel delivery if they still need to establish credit with a fuel supplier.
Do you have a written report addressing recommendations from your generator service provider on repairs or upgrades that should be considered for your emergency power system payment to a fuel supplier during a power outage to ensure timely fuel delivery?	Yes or Yes or No or No	During a power outage, generators with fuel supply may deplete limiting the emergency power system. Review that is not their primary supplier. In these situations, service providers will not deliver fuel or decrease a contract for repairs or delivery. Facilities should be addressed by having a means to make immediate payment for fuel delivery if they still need to establish credit with a fuel supplier.
Do you have a written protocol addressing how emergency power system testing in your facility is conducted?	Yes or Yes or No or No	If no, such a protocol should be developed immediately. This protocol should include explicit language guaranteeing the delivery of a temporary generator when needed. Including these clauses in rental agreements carries a cost, which is why many hospitals will not implement this type of contract. The only way to ensure that a rental generator will be made available to a facility during an outage is to execute the contract type of contract.
Are there updates to the facility or electrical infrastructure being planned, or that should be considered, that could potentially be completed during the emergency power system upgrade?	Yes or Yes or No or No	Infrastructure are being planned, discussions with a Mechanical, Electrical, and Plumbing (MEP) If yes, the facility should take planned opportunities to upgrade the facility's emergency power system.
In addition to conducting required testing on backup generators, do you routinely test switchgear equipment including automatic transfer switches?	Yes or No	If yes, the checklist of recommended maintenance activities and the list of scheduled maintenance activities should be provided for the facility administrator.
Has your facility performed maintenance on its emergency power system in accordance with the manufacturer's recommendations?	Yes or No	If no, the checklist of recommended maintenance activities that have not been completed should be provided, ask the generator service provider to test the facility and make suggestions be supplied by the facility's generator service provider. This step will also help determine how much cabling would be needed to connect a temporary generator.
Have you already identified locations for temporary generator installations on your campus?	Yes or No	A facility's generator service provider can be helpful in addressing these questions.
What levels of investment would be needed to make incremental or significant improvements to your facility's emergency power system?		

Part II Continued– Vulnerability Assessment with Suggested Mitigation Strategies to Address Vulnerabilities. (To be completed by Facility Director or other qualified personnel.) Completed document can help guide the Emergency Power System Review discussion.

Question	Answer	Suggested Mitigation Strategies to Address Vulnerabilities
Have appropriate personnel been trained on the manual operation of the diesel generators and overall emergency power system?	Yes or No	If no, schedule a training with your generator service provider as soon as possible to ensure that all engineering staff can manually operate the emergency power system.
Does your emergency power system have any unique cooling or operational requirements that may require special measures during a disaster (heat exchangers, cooling towers, etc.)?	Yes or No	If yes, discuss with your emergency power service provider and ensure that all engineering staff are aware of any unique requirements and can address these during a power outage. If unsure, check with your generator service provider.
Do you have a protocol established with input from your utility for detaching and reattaching to your electric utility during power outages?	Yes or No	If no, speak with your utility to determine what this protocol is. Be sure to document the protocol and ensure that all members of the engineering staff understand how to implement the protocol.
Is your water system dependent on power for water pressure due to building elevation? If so, is your water system supported by emergency power?	Yes or No	If no, ask your generator service provider, or an electrical contractor, whether your current emergency power system could accommodate any pumps needed to ensure proper water pressure. If there is no current capacity, ask for a cost proposal for expanding emergency power to enable the connection of water system pumps.
If your generator and its components, including fuel tanks, are not above the floodplain and safe from other water surges such as dam and water tower breaks, are system components encapsulated and protected from a flood?	Yes or No	If no, work with generator service providers or other contractors to install floodproofing devices.