

# NEWPORT CITY WATER SYSTEM - VT0005202

## Consumer Confidence Report - 2024

This report is a snapshot of the quality of the water that we provided in 2024. Included are the details about where your water comes from, what it contains, and how it compares to the Environmental Protection Agency (EPA) and state standards. We are committed to providing you with information because informed customers are our best allies. This report is designed to inform you about the quality water and services we deliver to you every day. To learn more, please attend any of our regularly scheduled meetings which are held:

1<sup>st</sup> and 3<sup>rd</sup> Monday of the month at 6:00 pm in the City Council Room.

The person who can answer questions about this report is: Thomas L. Bernier – Public Works Director

Telephone: (802) 334-2124 and/ or Email thomas.bernier@newportvermont.org

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place and distributing copies by hand or by mail.

As required by the Lead and Copper Rule Revision, we have prepared a service line inventory. The purpose of the inventory was to determine if any of our service lines contain lead, galvanized pipe requiring removal, or unknown materials. Please contact us if you would like access to this inventory.

## Water Source Information

Your water comes from:

| Source Name | Source Water Type |
|-------------|-------------------|
| WELL 2A     | Groundwater       |
| WELL 2      | Groundwater       |

The State of Vermont Water Supply Rule requires Public Community Water Systems to develop a Source Protection Plan. This plan delineates a source protection area for our system and identifies potential and actual sources of contamination. Please contact us if you are interested in reviewing the plan.

## Drinking Water Contaminants

The sources of drinking water (both tap water and bottled water) include surface water (streams, lakes) and ground water (wells, springs). As water travels over the land’s surface or through the ground, it dissolves naturally-occurring minerals. It also picks up substances resulting from the presence of animals and human activity. Some “contaminants” may be harmful. Others, such as iron and sulfur, are not harmful. Public water systems treat water to remove contaminants, if any are present.

In order to ensure that your water is safe to drink, we test it regularly according to regulations established by the U.S. Environmental Protection Agency and the State of Vermont. These regulations limit the amount of various contaminants:

- Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife
- Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides**, may come from a variety of sources such as storm water run-off, agriculture, and residential users.

**Radioactive contaminants**, which can be naturally occurring or the result of mining activity.

**Organic contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and also come from gas stations, urban storm water run-off, and septic systems.

## Water Quality Data

The table below lists all the drinking water contaminants that we detected during the past year. It also includes the date and results of any contaminants that we detected within the past five years if tested less than once a year. The presence of these contaminants in the water does not necessarily show that the water poses a health risk.

**Terms and abbreviations** - In this table you may find terms you might not be familiar with. To help you better understand these terms we have provided the following definitions:

**Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Contaminant:** Any physical, chemical, biological, or radiological substance or matter in water.

**Corrosion Control Efforts:** Treatment (including pH adjustment, alkalinity adjustment, or corrosion inhibitor addition) or other efforts contributing to the control of the corrosivity of water, e.g., monitoring to assess the corrosivity of water.

**Herbicide:** Any chemical(s) used to control undesirable vegetation.

**Level 1 Assessment:** A level 1 Assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

**Level 2 Assessment:** A Level 2 Assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

**Locational Running Annual Average (LRAA):** The average of sample analytical results for samples taken at a particular monitoring location during four consecutive calendar quarters.

**Maximum Contamination Level (MCL):** The “Maximum Allowed” MCL is the highest level of a contaminant that is allowed in drinking water. MCL’s are set as close to the MCLG’s as feasible using the best available treatment technology.

**Maximum Contamination Level Goal (MCLG):** The “Goal” is the level of a contaminant in drinking water below which there is no known or expected risk to human health. MCLG’s allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. Addition a disinfectant may help control microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of disinfectants in controlling microbial contaminants.

**Method Reporting Limit:** The lowest concentration of a chemical in a sample that a laboratory can reliably detect.

**Nephelometric Turbidity Unit (NTU):** NTU is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

**Parts per million (ppm) or Milligrams per liter (mg/l):** (one penny in ten thousand dollars)

**Parts per billion (ppb) or Micrograms per liter (µg/l):** (one penny in ten million dollars)

**Parts per trillion (ppt) or Nanograms per liter (ng/l):** (one penny in ten billion dollars)

**Pesticide:** Generally, any substance or mixture of substances intended for preventing, destroying, repelling, or mitigating any pest.

**Picocuries per liter (pCi/L):** a measure of radioactivity in water

**Running Annual Average (RAA):** The average of 4 consecutive quarters (when on quarterly monitoring); values in table represent the highest RAA for the year.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**90th Percentile:** Ninety percent of the samples are below the action level. (Nine of ten sites sampled were at or below this level).

**Per- and polyfluoroalkyl substances (PFAS):** PFAS are a group of human-made chemicals that have been in use since the 1940s. PFAS have been found in a wide variety of consumer products and as an ingredient in firefighting foam. PFAS manufacturing and processing facilities, airports, and military installations are some of the contributors of PFAS releases into the air, soil and water. Vermont currently regulates 5 PFAS and this list includes:

**Perfluorononanoic Acid (PFNA)**

**Perfluorooctanoic Acid (PFOA)**

**Perfluorooctane Sulfonic Acid (PFOS)**

**Perfluoroheptanoic Acid (PFHpA)**  
**Perfluorohexane Sulfonic Acid (PFHxS)**

## Detected Contaminants NEWPORT CITY WATER SYSTEM

| Disinfection Residual | RA A      | RANGE            | Unit     | MRDL | MRDL G | Typical Source                     |
|-----------------------|-----------|------------------|----------|------|--------|------------------------------------|
| Chlorine              | 0.17<br>2 | 0.010 -<br>0.640 | mg/<br>l | 4    | 4      | Water additive to control microbes |

| Chemical Contaminants | Collection Date | Highest Value | Range         | Unit | MC L | MCL G | Typical Source                                                                                                            |
|-----------------------|-----------------|---------------|---------------|------|------|-------|---------------------------------------------------------------------------------------------------------------------------|
| Arsenic               | 07/18/2024      | 2             | 2 - 2         | ppb  | 10   | 0     | Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.                   |
| Barium                | 10/26/2020      | 0.027         | 0.027 - 0.027 | ppm  | 2    | 2     | Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits                                |
| Ethylbenzene          | 03/28/2024      | 21.5          | 13.6 - 21.5   | ppb  | 700  | 700   | Discharge from petroleum refineries                                                                                       |
| Fluoride              | 12/30/2024      | 1.1           | 0.1 - 1.1     | ppm  | 4    | 4     | Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories |
| ISOPROPYLBENZENE      | 07/18/2024      | 0.5           | 0.5 - 0.5     | ppb  | NA   | NA    |                                                                                                                           |
| Xylenes               | 07/18/2024      | 0.193         | 0.182 - 0.193 | ppm  | 10   | 10    | Discharge from petroleum factories; Discharge from chemical factories                                                     |

| PFAS Contaminants |                                                                                          |
|-------------------|------------------------------------------------------------------------------------------|
| Typical Source    | A large group of human-made chemicals used widely in manufacturing and consumer products |
| MCL               | 20 (individual or sum of the 5 regulated PFAS compounds)                                 |
| Units             | All units in parts per trillion (ppt)                                                    |
| ND                | This means the contaminant was not detected at the laboratory Method Reporting Limit.    |

| Collection Date | PFHpA | PFNA | PFHxS | PFOA | PFO S | Sum of 5 regulated PFAS compounds |
|-----------------|-------|------|-------|------|-------|-----------------------------------|
| 11/16/2023      | ND    | ND   | ND    | ND   | ND    | ND                                |
| 10/22/2020      | ND    | ND   | ND    | ND   | ND    | ND                                |

\*Additional PFAS, not regulated by the Vermont Water Supply Rule, may also have been detected in the past five years. Please contact us if you would like more information on other unregulated PFAS that may be in your drinking water.

| Disinfection ByProducts      | Collection Year | Sample Location                  | Highest LRAA | Range | Unit | MCL | MCLG | Typical Source                            |
|------------------------------|-----------------|----------------------------------|--------------|-------|------|-----|------|-------------------------------------------|
| Total Trihalomethanes (TTHM) | 2024            | N COUNTRY HOSPITAL 189 PROUTY DR | 1            | 1 - 1 | ppb  | 80  | 0    | By-product of drinking water chlorination |

| Lead and Copper | Collection Date         | 90th Percentile | Range    | Unit | AL* | Sites Over AL | Typical Source                                                       |
|-----------------|-------------------------|-----------------|----------|------|-----|---------------|----------------------------------------------------------------------|
| Lead            | 08/24/2023 - 09/21/2023 | 2.3             | 0 - 6.4  | ppb  | 15  | 0             | Corrosion of household plumbing systems; Erosion of natural deposits |
| Copper          | 08/24/2023 - 09/21/2023 | 0.074           | 0 - 0.24 | ppm  | 1.3 | 0             | Corrosion of household plumbing systems; Erosion of natural deposits |

\*The lead and copper AL (Action Level) exceedance is based on the 90th percentile concentration, not the highest detected result.

\*\*Complete lead tap sampling data (i.e. each individual sample result) are available for review. Please contact us if you would like to receive this data.

## Violation(s) that occurred during the year

*We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. The below table lists any drinking water violations we incurred during 2024. A failure to perform required monitoring means we cannot be sure of the quality of our water during that time.*

| Type                  | Category                      | Analyte                        | Compliance Period       |
|-----------------------|-------------------------------|--------------------------------|-------------------------|
| LSL INVENTORY-INITIAL | Treatment Technique Violation | LEAD AND COPPER RULE REVISIONS | 10/17/2024 - 02/07/2025 |

**To be Completed by the Water System.** *List any steps taken to correct the violations listed above:*

## Health Information Regarding Drinking Water

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants, can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from EPA's Safe Drinking Water Hotline (1-800-426-4791).

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Safe Drinking Water Hotline or visiting the website at <https://www.epa.gov/safewater/lead>.

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. NEWPORT CITY WATER SYSTEM is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and

taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and you wish to have your water tested, contact NEWPORT CITY WATER SYSTEM. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

There is no safe level of lead in drinking water. Exposure to lead in drinking water can cause serious health effects in all age groups, especially pregnant people, infants (both formula-fed and breastfed), and young children. Some of the health effects to infants and children include decreases in IQ and attention span. Lead exposure can also result in new or worsened learning and behavior problems. The children of persons who are exposed to lead before or during pregnancy may be at increased risk of these harmful health effects. Adults have increased risks of heart disease, high blood pressure, kidney or nervous system problems. Contact your health care provider for more information about your risks.

## Uncorrected Significant Deficiencies

The system is required to inform the public of any significant deficiencies identified during a sanitary survey conducted by the Drinking Water and Groundwater Protection Division that have not yet been corrected. For more information please refer to the schedule for compliance in the system's Operating Permit.

| Date Identified | Significant Deficiencies                                                   | Facility            | Visit Reason    |
|-----------------|----------------------------------------------------------------------------|---------------------|-----------------|
| 02/14/2017      | Inadequate Cross-Connection Controls (inline booster pump(s))              | DISTRIBUTION SYSTEM | Sanitary Survey |
| 09/16/2019      | Inadequate Water Pressure (Under Normal, Peak, or Maximum Flow Conditions) | DISTRIBUTION SYSTEM | Sanitary Survey |

**To be Completed by the Water System.** *Describe any interim measures taken or work completed for the deficiencies listed above:*

**Public Notice - Permit to Operate Issued:** The Water System is required to notify all users of the following compliance schedule contained in the Permit to Operate issued by the State of Vermont Agency of Natural Resources:

To address the inadequate pressure served to the East Main Street / Derby Road area of the distribution system, the Permittee shall complete the following actions:

**On or before November 1, 2023**, the Permittee shall complete all work as authorized by the Construction Permit obtained.

**Within 60 days of project completion**, the Permittee shall submit all documents as required by the Construction Permit obtained per item 1.a. above.

**To be completed by the Water System:** The Derby Road water tower project will be completed this summer. This project will end the need for water from The Village of Derby.

Public Works Director  
Thomas L. Bernier  
(802) 334-2124

Chief Operator  
Jason Herman  
(802)334-8886