



Arkadelphia Public Schools
Director of Support Services
Jimmy King



May Maintenance Report

- All the materials for the repairs for the aux gym roof at AHS have finally come in. The contractor had a difficult time getting the foam board insulation panels needed but plan to begin that repair on May 28th.
- The dishwasher a Perritt broke down last week. Due to the cost to repair versus the number of days of school left. It was best to not repair the machine since we were leaving the building at the end of the school year.
- The air conditioning units at Perritt cafeteria, Peake kitchen, and Peake PE gym all broke down this week. All 3 units need to be replaced but thanks to Toby Daniell and Daniell Electric between his scrap pile and our scrap pile they were able to salvage enough parts to hopefully keep these units running until we can move out of both buildings this summer.
- I called Powers of Arkansas to come check two classroom units at Goza Middle School that we have had continuous problems with all year long. Powers was finally able to diagnose and fix the problem. They determined that both units were installed and programmed to operate as heat pumps when both are actually conventional units and not heat pumps.