

Best Management Practice (BMP) Summary Sheet

Municipal Separate Storm Sewer System (MS4) Name: University of Minnesota Twin Cities

Minimum Control Measure: 6-Pollution Prevention/Good Housekeeping

Unique BMP Identification Number: 6A.14 (MS4 Permit 2020: 21.4.c)

Date: 06/05/2026

BMP Title: Fueling System Spill Protection

BMP Description:

The University utilizes Underground Storage Tanks (USTs) and Above Ground Storage Tanks (ASTs) for vehicle and equipment fueling, which are included on the Facilities Inventory Map. Each outdoor fueling station is equipped with spill response supplies, and UST systems are also equipped with a spill bucket and overfill protection in accordance with Minnesota Pollution Control Agency (MPCA) Rules. ASTs are included in the University's Spill Prevention Control and Countermeasures (SPCC) Program, which includes monthly container integrity inspections and personnel training.

This is a systemwide BMP.

Measurable Goals:

Maintain spill response supplies at fueling sites.

Timeline/Implementation Schedule:

N/A

Specific Components and Notes:

Facilities Inventory Map/List

Health, Safety, and Risk Management (HSRM) Spill Response Program/SPCC Plan

BMP 6A.15 Vehicle Storage and Maintenance

BMP 6A.16 Equipment Storage and Maintenance

Responsible Party for this BMP:

Name: Linnea Weum

Department: Environmental Compliance Manager, Health, Safety, and Risk Management

E-mail: henke079@umn.edu