



Rm.22 Bathroom Sink	21970200-047BF	4/19/2022	ND
Rm.25 North Wall Sink	21970200-048CF	4/19/2022	1.11
Modular Rm.11 North Wall Sink	21970202-049CF	4/19/2022	ND
Modular Rm.11 Bathroom Sink	21970202-050BF	4/19/2022	ND
Modular Rm.12 South Wall Sink	21970202-051CF	4/19/2022	ND
Modular Rm.12 Bathroom Sink	21970202-052BF	4/19/2022	ND
Rm.16 East Wall Sink	21970201-053CF	4/19/2022	ND
Rm.16 Drinking Fountain	21970201-054DW	10/21/2022	1.13
Gym Fountain left	21970201-055DW	10/21/2022	1.04
Gym Fountain right	21970201-056DW	10/21/2022	1
Gym Bathroom by P.E Office	21970201-057BF	4/19/2022	ND
Rm.26 Bathroom Sink	21970201-058BF	4/19/2022	ND

**Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing**

<b>RETESTS</b>			

**ND = Non Detect - Lead level is below the set detection limits of 1 ppb**